MANITOBA HEALTH and HEALTHY LIVING

PUBLIC HEALTH DIVISION

COMMUNITY WATER FLUORIDATION PROGRAM

2007 / 2008

Manitoba

MG-2688 (Rev. 07/2008)

MANITOBA HEALTH and HEALTHY LIVING

PUBLIC HEALTH DIVISION

COMMUNITY WATER FLUORIDATION PROGRAM

2007 / 2008

Prepared by:
ALS Laboratory Group
(Manitoba Technology Centre Ltd.)
in conjunction with
Manitoba Health and Healthy Living

Manitoba

Health and Healthy Living
Public Health Division
Environmental Health Branch
Fourth Floor, 300 Carlton Street
Winnipeg MB R3B 3M9
CANADA
Telephone: 204- 788-6735
Fax: 204- 948-2040

Santé et Vie saine
Division de la santé publique
Santé environnementale
300, rue Carlton, 4e étage
Winnipeg MB R3B 3M9
CANADA
Téléphone : 204- 788-6735
Télécopieur : 204- 948-2040

July, 2008

Re: The Annual Fluoridation Report for the Province of Manitoba for the fiscal year 2007 - 2008.

This report is intended to be a resource for information regarding the Community Based Water Fluoridation Program in Manitoba which is sponsored and monitored by Manitoba Health and Healthy Living.

Please circulate your copy to any individual in your organization or facility who may have an interest in community dental health, public health, or community based programs.

Please contact Helen Browne, Administrative Assistant, Environmental Health Branch should you have any questions about water fluoridation in Manitoba either by telephone at 204-788-6735 or email Helen.browne@gov.mb.ca.

Thank you for your participation in the Community Based Water Fluoridation Program.

Yours truly,

James Drew
Director
Environmental Health Branch

TABLE OF CONTENTS

INTRODUCTION 1

I. STATUS OF FLUORIDATION IN MANITOBA 2
COMMUNITIES WITH A FLUORIDATED WATER SUPPLY TABLE I 3-5

II. FLUORIDATION GRANT
A. OVERVIEW 6
B. NEW PARTICIPANTS AND UPGRADES 6

III. EQUIPMENT
A. OVERVIEW 7
B. FLUORIDATION SYSTEMS 7
C. OPERATING PROBLEMS 8

IV. MONITORING PROGRAM
A. OVERVIEW 9
B. RESULTS 10

BI-WEEKLY SAMPLING RESULTS - 2007 / 2008 SUMMARY TABLE II 11

C. CERTIFICATES 2007 / 2008 12
EXCELLENCE RECIPIENTS 13
COMMENDATION RECIPIENTS 14

V. MANITOBA WATER SERVICES BOARD 15

VI. SUPPORT SERVICES 16

VII. FLUORIDE CONTROL DATA - 2007 / 2008 17
(Listed by location of the water treatment plant.)

FLUORIDE CONTROL DATA - 2007 / 2008 SUMMARY - TABLE III 18-19
FLUORIDE CONTROL DATA KEY 20

AUSTIN 21
BALDUR 22
BENITO 23
BINSCARTH 24
BIRTLE 25
BOISSEVAIN 26
BRANDON 27
CARMAN 28
CARTIER REGIONAL 29
CHURCHILL 30

TABLE OF CONTENTS continued

Page

CRANBERRY PORTAGE....31
CROSS LAKE RESERVE....32
DAUPHIN....33
DELORAINE....34
FLIN FLON....35
GILBERT PLAINS....36
GILLAM....37
GIMLI INDUSTRIAL PARK....38
GRISWOLD SIOUX VALLEY BAND....39

HAMIOTA....40
HARTNEY....41
KILLARNEY....42
LETELLIER-RRRWTP....43
LONG PLAIN....44
MANITOU....45
MELITA....46
MINNEDOSA....47
MORDEN....48
MORRIS....49
NEEPAWA....50
NORWAY HOUSE COMMUNITY COUNCIL....51

PILOT MOUND....52
PORTAGE LA PRAIRIE....53
RESTON....54
RIVERS....55
ROBLIN....56
ROSSBURN....57
RUSSELL....58
SANFORD (RM MACDONALD)....59
SAPOTAWEYAK....60
SHILO....61
SOMERSET....62
SOURIS....63

STEINBACH....64
STEPHENFIELD....65
SWAN RIVER....66
THE PAS....67
TREHERNE....68
VIRDEN....69
WABOWDEN....70
WINKLER....71
WINNIPEG....72
WINNIPEGOSIS....73

INTRODUCTION

This report is a brief summary of the performance of
Manitoba Health and Healthy Living's
Community Water Fluoridation Program
for the 2007 / 2008 fiscal year.

I. STATUS OF FLUORIDATION IN MANITOBA - 2007/2008

A total of fifty-three (53) water treatment plants provide fluoridated water to approximately eighty-nine (89) communities. Approximately 95% of the population served by a public water system receive fluoridated water. Population statistics are based on the 2006 census figures unless otherwise indicated. Included in the above statistics are an estimated number of rural residents who consume water transported from a fluoridated water supply.

Manitoba Health and Healthy Living operates a province-wide fluoride level monitoring program for all fluoridating communities. All online water treatment plants participated in the monitoring program.

Manitoba Health and Healthy Living offers a grant for communities wishing to install a fluoridation system in their communal water system. Assistance is provided in the design and selection of suitable fluoridation systems/equipment.

Training in equipment operation and maintenance, testing procedures, safety standards and monitoring protocol is provided initially to all communities. Technical assistance and support is then provided on an ongoing basis.

Manitoba Health and Healthy Living

Summary

Province of Manitoba

Communities with a Fluoridated Water Supply as of April 1, 2007

Table 1

NOTE: Population statistics are from 2006 census.

Water Plant Location	Status	Population	Ministerial Approval	Dates On-Line	Background Level	Chemical Feed	Average F mg/L	Water Source	Water Plant Owner
AUSTIN	Region	N/A	88/12/15	88/12/15	0.19	H2SiF6 25%	1.1	River	RM
BALDUR	Village	N/A	66/09/19	67/11/15	0.22	NaF 4 %	1.0	Well	RM
BENITO	Village	370	91/08/01	91/08/01	0.3	NaF 4 %	1.0	River	Village
BINSCARTH	Village	395	94/11/01	95/07/19	0.24	H2SiF6 25 %	0.8	Well	Village
BIRTLE	Town	662	89/05/04	87/11/07	0.26	NaF 4 %	0.8	Well	Town
BOISSEVAIN	Town	1497	56/11/05	57/01/11	0.2	NaF 4 %	1.0	SI	Town
BRANDON	City	41511	53/08/11	55/03/08	0.2	Na2SiF6 (Dry)	1.1	River	City
CARMAN	Town	2880	65/06/22	65/06/22	0.21	H2SiF6 25 %	1.1	River	Town
CARTIER REGIONAL	Region	N/A *	00/06/13	00/06/13	N/A	H2SiF6 25 %	1.0	River	Private
CHURCHILL	Town	923	94/11/01	95/10/04	< 0.10	H2SiF6 25 %	1.0	River	LGD
CRANBERRY PORTAGE	UVD	N/A	83/03/19	83/12/14	< 0.10	NaF 4 %	1.2	Lake	RM
CROSS LAKE RESERVE	Reserve	4000^	92/05/02	92/05/02	< 0.10	NaF 4 %	1.0	River	Reserve
DAUPHIN	City	7906	57/08/02	80/05/03	0.14	H2SiF6 25 %	1.1	SI	Town
DELORAINE	Town	977	67/07/28	68/09/24	0.16	NaF 4 %	1.0	SI	Town
FLIN FLON	City	5594	61/07/01	89/12/15	< 0.10	H2SiF6 25 %	1.1	Lake	City
GILBERT PLAINS	Village	760	89/02/22	89/02/22	0.19	NaF 4 %	0.8	Well	Village
GILLAM	LGD	1209	74/08/14	87/01/03	< 0.10	H2SiF6 25 %	1.2	River	LGD
GIMLI INDUSTRIAL PARK	Town	N/A	63/08/01	63/12/23	0.43	NaF 4 %	1.1	Well	Town
GRISWOLD SIOUX VALLEY BAND	Reserve	N/A	99/11/01	99/11/26	0.1	NaF 4 %	0.8	Well	Reserve
HAMIOTA	Village	823	70/05/27	70/08/17	0.29	NaF 4 %	1.1	Well	Town
HARTNEY	Town	400	64/01/02	64/12/16	0.2	NaF 4 %	1.2	Well	Town
KILLARNEY	Town	2199	60/10/12	60/10/25	0.19	NaF 4 %	1.2	Lake	Town
LETELLIER-RRRWTP	Region	N/A	89/05/04	87/05/13	0.17	H2SiF6 25 %	1.0	River	PVWC
LONG PLAIN	Reserve	752	94/03/02	94/03/02	0.23	NaF 4 %	1.1	Well	Reserve
MANITOU	Town	718	64/01/21	65/05/13	0.19	NaF 4 %	1.0	SI	Town

KEY:

1. Status
CFB - Canadian Forces Base
LGD - Local Government District
UVD - Unincorporated Village District

2. Type of Chemical Feed
H2SIF6 - Fluorosilicic Acid
NaF - Sodium Fluoride
Na2SiF6 - Sodium Fluorsilicate (Dry)

3. Water Plant Owner
MWSB - Manitoba Water Services Board
PVWC - Pembina Valley Water Co-op
RM - Rural Municipality

4. Water Source
SI - Surface Impoundment

Province of Manitoba

Communities with a Fluoridated Water Supply as of April 1, 2007

NOTE: Population statistics are from 2006 census.

Water Plant Location	Status	Population	Ministerial Approval	Dates On-Line	Background Level	Chemical Feed	Average F mg/L	Water Source	Water Plant Owner
MELITA	Town	1051	89/05/04	87/02/14	0.18	NaF 4 %	0.9	Well	Town
MINNEDOSA	Town	2474	60/01/25	86/04/01	0.28	H2SiF6 25 %	0.9	Well	Town
MORDEN	Town	6571	68/09/09	69/11/17	0.32	H2SiF6 25 %	1.0	Lake	Town
MORRIS	Region	1643	89/05/04	89/02/27	0.22	H2SiF6 25 %	1.1	River	PVWC
NEEPAWA	Town	3298	63/06/10	63/07/10	0.24	H2SiF6 25 %	0.8	Lake	Town
NORWAY HOUSE COMMUNITY COUNCIL	Town	N/A	95/01/01	95/09/01	0.21	H2SiF6 25 %	0.8	River	Town
PILOT MOUND	Town	630	68/10/25	70/12/21	0.21	NaF 4 %	0.9	SI	Town
PORTAGE LA PRAIRIE	City	12728	57/12/20	58/01/13	0.2	H2SiF6 25 %	1.1	River	City
RESTON	Village	N/A	67/09/13	68/11/26	0.13	NaF 4 %	1.0	Well	RM
RIVERS	Town	1193	68/06/07	86/10/27	0.18	NaF 4 %	1.1	Well	Town
ROBLIN	Town	1672	69/06/07	86/10/27	0.26	NaF 4 %	0.9	Well	Town
ROSSBURN	Town	546	89/05/04	77/12/05	0.1	NaF 4 %	1.0	Well	Town
RUSSELL	Town	1428	65/09/10	67/03/01	0.21	NaF 4 %	1.1	Well	Town
SANFORD (RM MACDONALD)	Region	5653	89/11/21	89/11/21	0.1	H2SiF6 25 %	1.0	River	RM
SAPOTAWEYAK	Reserve	N/A	03/12/18	03/12/18	0.31	NaF 4 %	0.7	River	Reserve
SHILO	CFB	N/A	69/01/14	69/01/14	0.05	NaF 4 %	1.0	Well	CFB
SOMERSET	Village	432	04/03/01	04/05/01	.02	H2SiF6 25 %	1.3	Well	MSWB
SOURIS	Town	1772	62/07/11	63/11/05	0.19	NaF 4 %	1.1	River	Town
STEINBACH	City	11066	59/11/04	60/05/23	0.39	H2SiF6 25 %	1.0	Well	City
STEPHENFIELD	Region	N/A	98/12/01	99/02/01	0.2	H2SiF6 25 %	0.9	River	PVWC
SWAN RIVER	Town	3859	80/10/07	82/08/08	0.18	H2SiF6 25 %	1.1	Well	Town
THE PAS	Town	5589	64/07/20	64/07/23	0.15	H2SiF6 25 %	1.1	River	Town
TREHERNE	Town	646	72/11/10	73/06/11	0.32	H2SiF6 25 %	1.0	Well	Town
VIRDEN	Town	3010	71/01/11	71/04/08	0.44	NaF 4 %	0.9	Well	Town
WABOWDEN	Village	N/A	89/06/30	89/06/30	< 0.10	H2SiF6 25 %	1.0	Lake	UVD

KEY:

1. Status
CFB - Canadian Forces Base
LGD - Local Government District
UVD - Unincorporated Village District

2. Type of Chemical Feed
H2SIF6 - Fluorosilicic Acid
NaF - Sodium Fluoride
Na2SiF6 - Sodium Fluorsilicate (Dry)

3. Water Plant Owner
MWSB - Manitoba Water Services Board
PVWC - Pembina Valley Water Co-op
RM - Rural Municipality

4. Water Source
SI - Surface Impoundment

Manitoba Health and Healthy Living

Summary

Province of Manitoba

Table 1

Communities with a Fluoridated Water Supply as of April 1, 2007

NOTE: Population statistics are from 2006 census.

Water Plant Location	Status	Population	Ministerial Approval	Dates On-Line	Background Level	Chemical Feed	Average F mg/L	Water Source	Water Plant Owner
WINKLER	City	9106	64/01/21	64/06/24	0.26	H2SiF6 25 %	0.9	Well	City
WINNIPEG	City	633451	56/07/20	56/12/28	0.1	H2SiF6 25 %	0.9	Lake	City
WINNIPEGOSIS	Village	628	89/05/04	88/08/10	0.15	NaF 4 %	1.1	Well	MSWB
*OTHER		1148***							

NOTES:

-The Red River Regional Water Treatment Plant in Letellier, Manitoba serves the following communities: Altona Rural Water Co-op, Dominion City,Gnadenfeld, Gnadenthal, Gretna Halbstadt-Marais Water Co-op, Horndean, Neubergthal, Plum Coulee, Rosenfeld, Roseau River Reserve, Sommerfeld, Town of Altona, Morden, Winkler and St. Jean

-The Regional Plant in Sanford also serves the communities of Brunkild, Domain, LaSalle, Oak Bluff and Starbuck

^ Cross Lake Community and Cross Lake Reserves combined have an approximate population of 4000.

* Cartier Regional provides water for several communities including Headingley, Elie, St. Eustache, St. Francois Xavier, Oakville, portions of the RM of Portage la Prairie and the RM of Grey.

KEY:

1. Status
CFB - Canadian Forces Base
LGD - Local Government District
UVD - Unincorporated Village District

2. Type of Chemical Feed
H2SIF6 - Fluorosilicic Acid
NaF - Sodium Fluoride
Na2SiF6 - Sodium Fluorsilicate (Dry)

3. Water Plant Owner
MWSB - Manitoba Water Services Board
PVWC - Pembina Valley Water Co-op
RM - Rural Municipality

4. Water Source
SI - Surface Impoundment

II.FLUORIDATION GRANT

Each fiscal year, grant monies are available through Manitoba Health and Healthy Living. The grant is a one time award to communities initiating a fluoridation system.

A.OVERVIEW

1)OBJECTIVE:
To have all communal water systems in the Province fluoridated.

2)ELIGIBILITY:
Any community with an existing water treatment plant that currently does not have an optimal fluoride level in the water supply is eligible,

3)DESCRIPTION:
If a community is interested in this grant, contact can be made with Manitoba Health and Healthy Living. Manitoba Health and Healthy Living will provide information on the grant program, make formal contact with the community and assist in the design, installation and operation of the equipment. Once the system is operational, payment will be authorized to the community for the initial purchase and installation of the equipment. Assistance is provided with ongoing monitoring of the fluoride levels in the water supply.

4) FUNDING:
The grant is based on actual initial costs of purchase and installation of equipment as submitted by communities.

5) MINISTERIAL APPROVAL:
Approval is issued by the Minister of Health to communities operating fluoridation systems in accordance with the regulations under the Manitoba Drinking Water Safety Act.

B.NEW PARTICIPANTS AND UPGRADES

1) No new water treatment plants introduced water fluoridation in 2007 - 2008.

NOTE: As of November 29, 2007, Austin receives water from Portage la Prairie Water Treatment Plant through the Yellowhead regional system.

III. EQUIPMENT

Fluoridation systems are periodically monitored and reassessed for efficiency. Efforts are made to upgrade older equipment to more efficient systems.

A. OVERVIEW

Water treatment plants are visited on a periodic basis for the purpose of encouraging preventive maintenance of the fluoridation systems.

Ongoing assistance is provided to ensure that adequate maintenance and safety practices are being followed. Testing procedures are also reviewed to ensure accurate monitoring of fluoride levels.

B. FLUORIDATION SYSTEMS

There are four types of fluoridation systems available. They are as follows:

a) Acid Feed

This system utilizes fluorosilicic acid (H_2SiF_6) as the chemical feed.

b) Batch Mix

This system utilizes sodium fluoride (NaF) as the chemical feed. This system is labour intensive and communities utilizing this system are encouraged to upgrade to either an acid feed or an upflow saturator system.

c) Dry Feed

This system utilizes sodium fluorosilicate (Na_2SiF_6) as the chemical feed. These systems were designed and installed in the 1950's and 1960's for larger treatment facilities. All remaining are fully functional with few operating problems.

d) Upflow Saturator

This system utilizes sodium fluoride (NaF) in a 4% solution as the chemical feed.

C. OPERATING PROBLEMS

Temporary operating problems may occur from time to time and are usually related to one of the following:

a) obsolete or malfunctioning fluoride feed equipment
b) obsolete or defective testing equipment
c) incorrect testing procedures
d) equipment breakdown
e) improper maintenance
f) changeover to a new system

Occasionally, fluoridation problems are related to water plant problems which are rectified when the plant's problems are corrected.

IV. MONITORING PROGRAM

A. OVERVIEW

The purpose of this program is to ensure that the recommended level for fluoride concentration is maintained in Manitoba's drinking water. All operating systems participated in the monitoring program.

1) Operating Parameters
Manitoba Health and Healthy Living identifies an operating range and an optimum level for fluoride concentration in drinking water. The optimum is 1 part per million (ppm) or 1 milligram per litre (mg/L). The operating range for 2007 / 2008 was set at 0.80 ppm as a minimum with 1.20 ppm as a maximum.

Water treatment plant operators are encouraged to maintain fluoride concentrations within the specified range.

Manitoba Health and Healthy Living provides a schedule for bi-weekly monitoring periods. The sampling year consisted of 27 periods this year.

2) Supplies
Manitoba Health and Healthy Living provides Fluoridation Control Record forms to the plants, to be submitted with the samples. Manitoba Health and Healthy Living also provides sampling bottles, fluoride standard solution, spadns (reagent) and shipping containers to the plants, through ALS Laboratory Group. All are necessary for daily testing and bi-weekly sample submission.

3) Sample Submission
Samples are collected on a daily basis, tested on-site and results are recorded by the water treatment plant operator. A 14 day composite sample (approximately one litre) is submitted bi-weekly by the community for analysis. A record of chemical feed data (Fluoridation Control Record) is submitted with the sample.

4) Analysis
ALS Laboratory Group, located in Winnipeg, receives the samples and conducts the analysis. The results are reported to the individual water treatment plant operators and to Manitoba Health and Healthy Living except for the City of Winnipeg who does their own testing.

5) Monitoring
Manitoba Health and Healthy Living monitors the levels, makes recommendations, and provides technical assistance accordingly.

6) Reporting
Communities receive an annual report of their plant's operating record. On a periodic and/or as required basis, reports are provided during the operating year.

B. RESULTS

In 2007 / 2008, out of a possible 1,431 samples, 1,343 bi-weekly samples were received for a submission rate of 93.8%.

Of the total submitted 1,150 or 85.6% were within the recommended range for fluoride concentration.

The number of samples found to be above the range was 103, representing 7.7% of the total.

There were 90 samples found to be below the range representing 6.7% of all samples submitted.

Samples of .7 ppm will be acceptable for purposes of certificate eligibility.

Bi-Weekly Sampling Results Summary 2007 / 2008

Table 2

Town	No. of Samples Within Limits	No. of Samples Above Limits	No. of Samples Below Limits	No. of Samples Submitted	No. of Samples Possible
AUSTIN	11	6	2	19	27
BALDUR	26	0	1	27	27
BENITO	27	0	0	27	27
BINSCARTH	25	0	2	27	27
BIRTLE	2	0	1	3	27
BOISSEVAIN	27	0	0	27	27
BRANDON	23	2	1	26	27
CARMAN	26	1	0	27	27
CARTIER REGIONAL	23	1	3	27	27
CHURCHILL	27	0	0	27	27
CRANBERRY PORTAGE	19	8	0	27	27
CROSS LAKE RESERVE	20	4	3	27	27
DAUPHIN	24	3	0	27	27
DELORAINE	27	0	0	27	27
FLIN FLON	26	1	0	27	27
GILBERT PLAINS	19	0	8	27	27
GILLAM	24	3	0	27	27
GIMLI INDUSTRIAL PARK	25	2	0	27	27
GRISWOLD SIOUX VALLEY BAND	8	1	4	13	27
HAMIOTA	23	4	0	27	27
HARTNEY	21	6	0	27	27
KILLARNEY	16	9	2	27	27
LETELLIER-RRRWTP	26	0	1	27	27
LONG PLAIN	20	4	2	26	27
MANITOU	25	2	0	27	27
MELITA	20	0	7	27	27
MINNEDOSA	13	0	1	14	27
MORDEN	27	0	0	27	27
MORRIS	23	4	0	27	27
NEEPAWA	18	0	9	27	27
NORWAY HOUSE COMMUNITY COUNCIL	3	0	3	6	27
PILOT MOUND	17	2	8	27	27
PORTAGE LA PRAIRIE	19	6	2	27	27
RESTON	26	1	0	27	27
RIVERS	24	3	0	27	27
ROBLIN	27	0	0	27	27
ROSSBURN	26	1	0	27	27
RUSSELL	25	1	0	26	27
SANFORD (RM MACDONALD)	27	0	0	27	27
SAPOTAWEYAK	11	0	14	25	27
SHILO	23	0	3	26	27
SOMERSET	16	11	0	27	27
SOURIS	21	6	0	27	27
STEINBACH	27	0	0	27	27
STEPHENFIELD	21	0	6	27	27
SWAN RIVER	22	5	0	27	27
THE PAS	26	1	0	27	27
TREHERNE	27	0	0	27	27
VIRDEN	26	0	0	26	27
WABOWDEN	21	3	2	26	27
WINKLER	23	0	4	27	27
WINNIPEG	27	0	0	27	27
WINNIPEGOSIS	24	2	1	27	27

C. CERTIFICATES

Manitoba Health and Healthy Living annually presents certificates to recognize water treatment plant operators who have maintained a high standard of operating efficiency for a fluoridation system.

To be eligible for a certificate, a plant must be participating for 50% of the sampling year.

For the 2007 / 2008 sampling year this represented 27 periods.

There were 53 plants eligible for the certificates in 2007 / 2008. The Altona plant is not eligible for the certificate program because it is a sampling location only.

1) CERTIFICATE OF EXCELLENCE

The selection criteria are:
A) 100% of bi-weekly samples must be submitted for the sampling year
and
B) 100% of submitted samples must be within the recommended operating range for fluoride concentration

In 2007 / 2008 certificates of excellence were presented to 13 water plant supervisors/operators. This represents 25% of the total number of eligible community fluoridation systems. Allowances are made on the presentation of certificates when justifiable explanations are provided.

2) CERTIFICATE OF COMMENDATION

The selection criteria are:
A) 85% or 23 out of 27 bi-weekly samples must be submitted for the sampling year, and
B) 90% of submitted samples must be within the recommended operating range for fluoride concentration.

In 2007 / 2008 certificates of commendation were presented to 24 water plant supervisors/operators. This represents 45% of the total number of eligible community fluoridation systems. Allowances are made on the presentation of certificates when justifiable explanations are provided. Occasional readings of .7 ppm are considered acceptable for certificate eligibility.

The total number of certificates presented was 37 out of a possible 53. Thus, 70% of the operators/supervisors were awarded with recognition certificates.

Certificates of Excellence

2007 / 2008 Recipients

Recipient	Plant Location	Operating Authority
Raymond Lussier	BALDUR	Rural Municipality
Rick Kinaschuk	BENITO	Village
Steve Stewart	BINSCARTH	Village
Barry Chinner	BOISSEVAIN	Town
William Ayotte	CHURCHILL	Local Government District
Kent Corkish	DELORAINE	Town
Kurt Henry	LETELLIER-RRRWTP	PVWC
Al Spearman	MORDEN	Town
Don Todorovich	ROBLIN	Town
David Eppler	SANFORD (RM MACDONALD)	Rural Municipality
Jason Hiebert	STEINBACH	City
Ken Lawrence	TREHERNE	Town
Renee Grosselle	WINNIPEG	City

Certificates of Commendation

2007 / 2008 Recipients

Recipient	Plant Location	Operating Authority
Brad McIntosh	BRANDON	City
Bob Lambert	CARMAN	Town
Dave Pirt	CARTIER REGIONAL	Private
Bill Brenner	DAUPHIN	Town
Kevin Komarnicki	FLIN FLON	City
Lloyd Beckley	GILBERT PLAINS	Village
John McDonald	GILLAM	Local Government District
Richard Bezdietny	GIMLI INDUSTRIAL PARK	Town
Ken Curle	HAMIOTA	Town
Keith Cowper	MANITOU	Town
Bob Reddaway	MELITA	Town
Byron Klassen	MORRIS	PVWC
Dan Wagner	NEEPAWA	Town
Corey McCoy	PILOT MOUND	Town
Ken Moore	RESTON	Rural Municipality
Randy King	RIVERS	Town
Perry Kretai	ROSSBURN	Town
Mark Moan	RUSSELL	Town
Bill Burke	SHILO	CFB
Paul Termeer	STEPHENFIELD	PVWC
Ronald Stewart	THE PAS	Town
Norm Baxter	VIRDEN	Town
Travis Duff	WINKLER	City
Dan Rempel	WINNIPEGOSIS	MSWB

V. Manitoba Water Services Board

Manitoba Water Services Board owns a number of treatment facilities across Manitoba and provides water to communities.

In communities currently fluoridating, Manitoba Water Services Board works cooperatively with Manitoba Health and Healthy Living to ensure that the requirements of the fluoridation monitoring system are met.

In communities wishing to fluoridate, Manitoba Water Services Board works in conjunction with Manitoba Health and Healthy Living to assess the water treatment facility design the fluoridation system and coordinate installation and start-up.

Manitoba Water Services Board plant operators are trained by Manitoba Health and Healthy Living staff in proper testing, operating and maintenance procedures for their specific fluoridation systems.

VI. SUPPORT SERVICES

Manitoba Health and Healthy Living wishes to acknowledge the support received from various groups and government departments which provided assistance with the performance of the Community Water Fluoridation Program:

i. Mayors, Community Councils, Waterworks Chairpersons, Band Councils, and especially water treatment plant operators and supervisors in all locations with community water fluoridation systems in operation.

ii. Manitoba Water Services Board for the cooperative efforts made to ensure Manitoba Health and Healthy Living standards were observed in all fluoridating locations.

iii. ALS Laboratory Group for the provision of fluoride level analyses, the distribution of reagents, sample bottles and fluoride results to participating communities, the preparation of this report and other administrative services.

iv. Manitoba Water Stewardship for the provision of inspection and surveillance services in water plants, as well as consultation services.

v. Medical Services Branch, Health Canada for the promotion of fluoridation on Manitoba First Nation communities.

vi. Equipment manufacturers and suppliers for assistance with system design, especially Prairie Chem Inc. for promotion services and consultation assistance.

All of the above individuals and agencies have been instrumental in the provision of this important preventive dental health measure to the citizens of Manitoba.

FOR FURTHER INFORMATION REGARDING MANITOBA'S COMMUNITY WATER FLUORIDATION PROGRAM PLEASE CONTACT:

Manitoba Health and Healthy Living
Public Health Division
300 Carlton Street
Winnipeg MB R3B 3M9

Telephone: (204) 788-6735
Fax: (204) 948-2040
Email: Helen.Browne@gov.mb.ca

VII

FLUORIDE

CONTROL

DATA

2007 / 2008

Manitoba Health and Healthy Living Fluoride Monitoring Program

Table 3

Fluoride Control Data Laboratory Results - 2007 / 2008 - Summary

The figures in this table reflect results of the testing of bi-weekly composite samples for fluoride concentration in parts per million

Location / Period Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27
AUSTIN	1.0	0.9	1.0	1.0	1.0	1.0	0.9	0.7	1.2	1.3	1.2	0.7	1.2	1.2	1.3	1.4	1.3	1.6	1.5								
BALDUR	0.9	0.9	0.9	1.0	1.0	1.0	0.9	1.1	0.8	0.7	0.8	0.8	1.1	1.1	1.2	1.2	1.1	1.1	1.2	1.2	1.1	1.0	0.9	0.9	1.0	0.9	1.0
BENITO	1.1	1.0	1.1	1.2	1.2	1.1	1.0	1.0	1.0	0.9	1.0	0.9	1.1	1.1	1.1	1.0	1.1	1.1	1.1	1.2	1.0	1.0	0.9	1.0	1.0	1.0	1.0
BINSCARTH	1.0	1.0	0.9	0.9	1.0	0.8	0.8	0.9	0.7	0.7	0.8	0.9	0.8	0.8	0.8	0.9	0.9	0.9	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
BIRTLE	0.8	0.5	1.0																								
BOISSEVAIN	1.0	1.0	0.9	1.0	1.1	1.0	0.9	1.0	0.9	0.9	1.0	1.0	1.1	1.0	1.1	1.1	1.1	1.1	1.1	1.2	1.0	0.9	1.0	1.0	1.0	1.0	1.0
BRANDON	1.1	0.9	1.2	1.2	1.2	1.2	0.9	1.1	1.0	1.0	1.0	1.0	0.9	1.1	1.1	1.2	1.3	1.2	0.7		1.2	1.3	1.2	1.1	1.1	1.2	1.2
CARMAN	1.0	1.1	1.2	1.1	1.0	1.2	1.3	1.2	1.0	1.0	1.0	1.1	1.2	1.2	1.2	0.9	0.9	1.0	1.0	1.0	0.9	0.9	1.0	1.0	1.0	1.1	1.0
CARTIER REGIONAL	0.9	1.9	1.0	1.0	1.1	1.0	0.9	0.9	0.9	1.0	0.8	1.1	1.1	1.2	1.1	1.0	1.1	1.2	1.2	1.1	0.9	0.8	0.8	0.7	0.6	1.0	0.7
CHURCHILL	1.0	0.9	1.0	1.0	1.0	1.0	1.0	1.1	1.0	0.9	0.9	0.9	0.9	0.9	1.0	0.9	0.9	1.0	0.9	0.8	1.1	1.2	1.0	1.2	1.1	1.2	1.2
CRANBERRY PORTAGE	1.1	1.3	1.1	1.2	1.1	1.1	1.1	1.1	1.0	1.0	1.1	1.3	1.4	1.4	1.3	1.3	1.3	1.6	1.0	1.1	1.1	1.1	1.0	1.2	1.2	1.1	1.0
CROSS LAKE RESERVE	1.1	1.0	1.2	1.0	1.0	1.0	0.5	0.8	0.7	1.2	1.1	0.8	1.1	1.0	1.3	0.9	1.4	1.2	1.3	0.9	0.6	1.0	1.0	0.9	1.1	1.3	1.1
DAUPHIN	1.1	1.1	1.1	1.1	1.2	1.1	1.0	1.1	1.0	1.0	1.1	1.0	1.2	1.2	1.2	1.2	1.2	1.3	1.3	1.3	1.1	1.1	1.0	1.0	1.0	1.0	1.1
DELORAINE	1.0	1.1	0.9	0.9	1.0	1.0	0.9	0.9	0.9	0.9	1.0	0.9	1.0	1.1	1.0	1.1	1.1	1.1	1.1	1.2	1.0	1.0	1.0	1.0	1.0	1.1	1.0
FLIN FLON	1.1	1.0	1.0	1.2	1.1	1.0	0.9	1.0	0.8	0.9	1.1	1.0	1.1	1.1	1.2	1.1	1.2	1.2	1.2	1.4	1.0	1.0	0.9	0.9	1.1	1.0	1.0
GILBERT PLAINS	0.7	0.7	0.5	0.7	0.9	0.9	0.8	1.0	1.0	0.6	0.8	0.9	0.6	1.0	1.0	1.0	0.9	0.9	0.8	0.6	0.9	0.9	0.8	0.8	0.8	0.8	0.7
GILLAM	1.1	1.1	1.1	1.2	1.2	1.1	1.1	1.2	1.1	1.0	1.0	1.0	1.2	1.2	1.2	1.2	0.8	2.4	1.9	1.4	1.2	1.1	1.0	1.0	1.1	1.0	1.2
GIMLI INDUSTRIAL PARK	1.0	0.9	1.0	1.2	1.2	1.2	1.1	1.0	0.9	1.1	1.1	0.9	1.1	1.3	1.2	1.2	1.0	1.1	0.9	1.3	1.1	1.0	1.0	1.0	1.0	0.9	1.0
GRISWOLD SIOUX VALLEY BAND			1.0		1.0			0.5	0.4	0.7	0.8	0.7		1.0	0.8		1.1	0.8	1.3			0.8					
HAMIOTA	0.8	1.5	1.7	1.2	1.0	1.0	0.9	0.9	0.8	0.8	0.8	0.9	1.1	1.1	1.1	1.1	1.0	1.2	1.1	1.3	1.2	1.1	0.9	1.5	1.0	1.0	1.1
HARTNEY	2.3	2.3	1.9	1.2	1.1	1.1	1.0	1.2	1.2	1.1	1.2	0.9	1.5	1.0	1.0	1.0	1.2	1.4	1.2	1.4	1.0	0.8	0.8	1.0	1.0	1.0	1.1
KILLARNEY	0.8	0.3	0.8	0.7	1.1	1.6	1.7	1.4	1.5	1.1	1.2	1.4	1.8	1.9	1.1	1.3	1.1	1.0	1.1	1.0	1.0	0.9	0.8	1.1	1.2	1.0	1.3
LETELLIER-RRRWTP	1.1	1.0	1.0	1.1	1.2	1.2	1.1	1.2	1.1	1.0	1.0	1.1	1.2	1.2	1.2	1.2	1.2	0.8	0.9	1.0	0.9	0.8	0.8	0.8	0.8	0.9	0.7
LONG PLAIN	1.2		1.0	1.0	1.1	1.1	1.0	0.9	1.1	0.9	0.7	0.8	1.1	1.0	1.1	0.9	1.1	0.7	0.8	1.5	1.2	1.0	0.8	1.0	1.4	1.6	1.5
MANITOU	1.2	1.1	1.1	1.2	1.2	1.1	0.9	0.8	0.8	1.1	1.0	0.9	1.1	1.0	1.3	1.2	1.0	1.2	1.2	1.3	1.0	0.9	0.9	0.9	0.9	1.0	1.0
MELITA	1.1	1.2	1.2	1.2	1.1	1.1	1.0	0.9	0.8	0.8	1.0	0.8	1.1	1.2	1.0	0.6	0.7	0.8	0.6	0.7	0.9	0.9	0.8	0.7	0.5	0.9	0.7
MINNEDOSA	0.9	0.9	1.0	0.9	1.0	1.0	0.9	1.0	0.8	0.7	0.8	0.8	0.8	0.9													
MORDEN	1.0	1.1	1.0	1.0	1.0	1.0	0.9	1.1	1.0	0.9	1.0	0.9	1.1	1.1	1.1	1.2	1.2	1.1	1.1	1.2	1.0	1.0	1.0	1.0	1.0	1.1	1.0
MORRIS	1.2	1.2	1.2	1.2	1.3	1.3	1.3	1.3	1.1	1.0	1.0	1.0	1.2	1.2	1.2	1.1	1.1	1.2	1.2	1.0	1.0	0.8	1.0	1.0	1.0	1.1	1.0
NEEPAWA	0.9	0.8	0.8	0.6	0.9	0.7	0.8	0.8	0.6	0.6	0.7	0.8	0.9	0.9	0.7	1.0	0.9	0.8	1.1	0.9	0.7	0.8	0.9	0.9	0.7	1.1	0.7

Manitoba Health and Healthy Living Fluoride Monitoring Program

Table 3

Fluoride Control Data Laboratory Results - 2007 / 2008 - Summary

The figures in this table reflect results of the testing of bi-weekly composite samples for fluoride concentration in parts per million

Location / Period Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27
NORWAY HOUSE COMMUNITY COUNCIL																						0.8	0.7	0.7	0.7	0.8	1.0
PILOT MOUND	0.6	0.7	1.0	0.9	0.9	1.3	1.1	1.1	1.0	0.8	0.9	0.9	1.1	0.7	0.7	1.2	2.4	0.9	0.4	0.7	0.7	0.7	0.8	0.9	0.8	1.0	1.0
PORTAGE LA PRAIRIE	0.9	1.5	1.2	1.2	1.1	1.2	1.2	1.0	1.2	1.0	1.0	1.1	1.3	1.2	1.3	1.4	1.3	1.3	1.2	1.0	0.9	0.6	0.8	0.9	0.8	1.0	0.7
RESTON	0.9	0.8	0.8	1.2	1.1	1.0	1.0	1.0	1.0	0.9	1.0	1.0	1.1	1.0	1.0	1.0	1.2	1.2	1.2	1.4	0.9	1.1	1.2	1.0	1.1	0.9	1.1
RIVERS	0.8	1.0	1.0	1.0	1.0	1.3	1.0	1.2	1.1	0.9	1.0	0.9	1.2	1.2	1.1	1.1	1.2	1.8	1.3	1.2	1.0	0.8	1.0	1.0	1.0	1.0	1.0
ROBLIN	0.9	0.9	0.9	1.0	0.9	1.0	0.9	0.8	0.9	0.9	1.0	1.0	1.1	1.0	1.0	1.1	1.0	1.1	0.9	1.1	0.9	0.9	0.8	0.8	0.8	1.0	1.0
ROSSBURN	1.0	0.9	0.9	1.0	0.9	0.9	1.0	1.0	0.9	0.9	1.0	1.0	1.1	0.9	0.9	0.8	0.9	0.9	1.2	1.2	1.0	0.8	1.3	1.1	1.0	1.0	1.0
RUSSELL	1.0	1.1	1.2	1.2	1.1	1.1	1.2	1.2	1.0	1.0	1.0	1.1	1.3	1.2	1.2	1.1	1.1	1.2	1.1		1.0	1.1	1.0	1.0	1.1	1.0	1.1
SANFORD (RM MACDONALD)	1.0	0.9	1.0	1.0	1.0	1.1	0.9	1.1	1.0	0.9	0.9	0.9	1.1	1.1	1.1	1.1	1.1	1.1	1.2	1.0	1.0	1.0	1.0	1.0	0.9	1.0	1.0
SAPOTAWEYAK	0.8	0.7	0.7	0.7	0.9	0.8	0.7	0.6	0.5	0.6			0.7	0.8	0.9	0.8	0.5	0.4	0.9	0.8	0.7	0.3	0.2	0.6	1.0	1.0	1.0
SHILO	0.7		0.8	1.0	0.9	1.1	1.0	1.1	0.8	0.6	0.5	1.0	1.1	1.2	1.2	1.1	1.1	1.0	1.1	1.2	1.0	1.0	1.0	1.0	1.0	1.0	1.0
SOMERSET	1.4	1.4	1.4	1.9	2.0	2.0	1.9	1.8	1.7	1.5	1.7	1.1	1.0	1.1	0.9	0.9	1.0	1.0	1.0	1.0	0.9	0.8	0.8	0.9	1.0	1.0	1.0
SOURIS	0.8	1.0	1.0	1.0	1.0	1.0	1.0	1.2	0.9	0.9	1.0	1.2	1.1	1.2	1.3	1.3	1.2	1.4	1.5	1.4	1.1	1.3	1.1	1.0	1.1	1.2	1.0
STEINBACH	0.9	1.0	1.0	0.9	1.0	1.0	0.9	0.9	1.0	0.8	1.0	0.9	1.1	1.0	1.0	1.0	1.0	0.9	1.1	1.0	0.9	0.8	1.0	0.8	0.9	0.9	1.0
STEPHENFIELD	1.2	1.2	1.2	1.2	1.1	1.0	0.9	1.1	1.0	0.9	1.0	1.0	1.1	1.0	1.1	1.0	1.0	0.8	0.8	0.7	0.7	0.7	0.6	0.7	0.6	0.8	0.9
SWAN RIVER	1.3	1.2	1.3	1.0	1.0	1.2	1.1	1.2	1.0	0.9	1.0	1.0	1.1	1.2	1.3	1.2	1.3	1.3	1.2	1.2	0.9	0.9	0.9	0.9	0.9	1.0	1.0
THE PAS	1.0	1.0	1.1	1.1	1.2	1.2	1.0	1.2	1.0	1.0	1.0	1.1	1.2	1.2	1.2	1.0	1.1	1.2	1.2	1.4	1.1	1.0	1.0	1.0	1.0	1.1	1.0
TREHERNE	0.9	0.9	1.0	1.0	1.0	0.9	0.9	1.0	0.9	0.8	0.9	0.8	1.1	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	1.0	0.9	1.0	1.0	1.0	1.0
VIRDEN	0.8	1.0	1.0	0.9	1.0	0.9	0.8		0.8	0.9	1.0	0.8	1.0	0.9	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.9	0.9	0.8	0.9	1.0	1.0
WABOWDEN	1.1	1.2	1.4	1.4	1.0	1.0	0.9	0.9	1.0	0.6	0.8	0.9	1.1	1.2	1.3		0.1	1.0	1.1	1.2	1.0	1.1	1.0	0.9	0.8	0.9	1.1
WINKLER	0.9	0.9	1.0	1.1	1.1	1.1	1.0	0.9	0.8	0.7	0.8	0.8	0.8	1.0	0.9	0.9	0.7	1.0	0.9	1.1	0.9	0.9	0.8	0.6	0.6	0.8	1.0
WINNIPEG	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.9	0.9	0.9	0.9	0.8	0.9	0.8	0.8	0.8	0.9	0.9	0.9	0.8	0.8	0.9	0.8	0.8	0.8	0.9
WINNIPEGOSIS	1.1	1.2	1.3	1.2	1.1	1.2	1.2	1.3	1.0	1.1	1.1	1.0	1.2	1.2	1.1	1.1	1.1	1.2	1.1	1.2	0.9	0.9	0.8	0.7	0.8	1.0	1.1

FLUORIDATION CONTROL DATA - KEY

All figures reported are recorded in parts per million (ppm) or milligrams per litre (mg/L).

COMPOSITE (LAB)
Fluoride level analysis conducted by ALS Laboratory Group on the bi-weekly composite sample submitted by the water plant operator.

COMPOSITE (OPERATOR)
Fluoride level analysis conducted and reported by the water treatment plant operator on the bi-weekly sample before it is submitted to ALS Laboratory Group.

NOTE: If "NOT AVAILABLE" appears in any column, it indicates that data is not available due to one of the following reasons:

- sample not submitted
- sample broken in transit
- information not provided
- sample was contaminated

Fluoride Control Data 2007 / 2008

LOCATION AUSTIN
OPERATOR Ed Sattler
PHONE 637-2461

FLUORIDATOR LMI A151
CHEMICAL H2SiF6 25%
NATURAL FLUORIDE 0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	0.86
2	MAR 31 - APR 13	0.9	0.84
3	APR 14 - APR 27	1.0	1.15
4	APR 28 - MAY 11	1.0	0.92
5	MAY 12 - MAY 25	1.0	0.82
6	MAY 26 - JUN 8	1.0	0.75
7	JUN 9 - JUN 22	0.9	0.83
8	JUN 23 - JUL 6	0.7	0.78
9	JUL 7 - JUL 20	1.2	0.87
10	JUL 21 - AUG 3	1.3	1.19
11	AUG 4 - AUG 17	1.2	0.89
12	AUG 18 - AUG 31	0.7	1.00
13	SEP 1 - SEP 14	1.2	0.82
14	SEP 15 - SEP 28	1.2	0.77
15	SEP 29 - OCT 12	1.3	1.00
16	OCT 13 - OCT 26	1.4	0.98
17	OCT 27 - NOV 9	1.3	0.00
18	NOV 10 - NOV 23	1.6	1.00
19	NOV 24 - DEC 7	1.5	0.79
20	DEC 8 - DEC 21	NOT AVAILABLE	NOT AVAILABLE
21	DEC 22 - JAN 4	NOT AVAILABLE	NOT AVAILABLE
22	JAN 5 - JAN 18	NOT AVAILABLE	NOT AVAILABLE
23	JAN 19 - FEB 1	NOT AVAILABLE	NOT AVAILABLE
24	FEB 2 - FEB 15	NOT AVAILABLE	NOT AVAILABLE
25	FEB 16 - FEB 29	NOT AVAILABLE	NOT AVAILABLE
26	MAR 1 - MAR 14	NOT AVAILABLE	NOT AVAILABLE
27	MAR 15 - MAR 28	NOT AVAILABLE	NOT AVAILABLE

Summary for AUSTIN

Average	1.1	0.86
Minimum	0.7	0.00
Maximum	1.6	1.19
Samples Above Limit	6	
Samples Below Limits	2	
% Outside Limits:	42%	
Number of Samples	19	

Fluoride Control Data 2007 / 2008

LOCATION BALDUR
OPERATOR Raymond Lussier
PHONE 535-2176

FLUORIDATOR LMI A151
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.22

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	0.82
2	MAR 31 - APR 13	0.9	0.89
3	APR 14 - APR 27	0.9	0.82
4	APR 28 - MAY 11	1.0	0.85
5	MAY 12 - MAY 25	1.0	0.86
6	MAY 26 - JUN 8	1.0	0.88
7	JUN 9 - JUN 22	0.9	0.84
8	JUN 23 - JUL 6	1.1	0.90
9	JUL 7 - JUL 20	0.8	0.81
10	JUL 21 - AUG 3	0.7	0.87
11	AUG 4 - AUG 17	0.8	0.82
12	AUG 18 - AUG 31	0.8	0.84
13	SEP 1 - SEP 14	1.1	0.94
14	SEP 15 - SEP 28	1.1	0.93
15	SEP 29 - OCT 12	1.2	1.03
16	OCT 13 - OCT 26	1.2	0.94
17	OCT 27 - NOV 9	1.1	0.91
18	NOV 10 - NOV 23	1.1	1.44
19	NOV 24 - DEC 7	1.2	0.90
20	DEC 8 - DEC 21	1.2	0.88
21	DEC 22 - JAN 4	1.1	0.94
22	JAN 5 - JAN 18	1.0	0.97
23	JAN 19 - FEB 1	0.9	0.85
24	FEB 2 - FEB 15	0.9	0.84
25	FEB 16 - FEB 29	1.0	0.92
26	MAR 1 - MAR 14	0.9	0.94
27	MAR 15 - MAR 28	1.0	0.94

Summary for BALDUR

Average	1.0	0.91
Minimum	0.7	0.81
Maximum	1.2	1.44
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	4%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION BENITO
OPERATOR Rick Kinaschuk
PHONE 539-2634

FLUORIDATOR LMI A151
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.3

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	1.10
2	MAR 31 - APR 13	1.0	1.00
3	APR 14 - APR 27	1.1	1.10
4	APR 28 - MAY 11	1.2	1.10
5	MAY 12 - MAY 25	1.2	1.10
6	MAY 26 - JUN 8	1.1	1.00
7	JUN 9 - JUN 22	1.0	1.00
8	JUN 23 - JUL 6	1.0	1.00
9	JUL 7 - JUL 20	1.0	1.00
10	JUL 21 - AUG 3	0.9	1.00
11	AUG 4 - AUG 17	1.0	1.00
12	AUG 18 - AUG 31	0.9	1.00
13	SEP 1 - SEP 14	1.1	1.00
14	SEP 15 - SEP 28	1.1	1.00
15	SEP 29 - OCT 12	1.1	1.10
16	OCT 13 - OCT 26	1.0	0.90
17	OCT 27 - NOV 9	1.1	1.00
18	NOV 10 - NOV 23	1.1	1.10
19	NOV 24 - DEC 7	1.1	1.10
20	DEC 8 - DEC 21	1.2	1.00
21	DEC 22 - JAN 4	1.0	1.00
22	JAN 5 - JAN 18	1.0	1.10
23	JAN 19 - FEB 1	0.9	1.00
24	FEB 2 - FEB 15	1.0	1.10
25	FEB 16 - FEB 29	1.0	1.10
26	MAR 1 - MAR 14	1.0	1.00
27	MAR 15 - MAR 28	1.0	1.10

Summary for BENITO

Average	1.0	1.04
Minimum	0.9	0.90
Maximum	1.2	1.10
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	BINSCARTH	FLUORIDATOR	Prom Gamma
OPERATOR	Steve Stewart	CHEMICAL	H2SiF6 25 %
PHONE	532-2223	NATURAL FLUORIDE	0.24

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.09
2	MAR 31 - APR 13	1.0	1.01
3	APR 14 - APR 27	0.9	1.05
4	APR 28 - MAY 11	0.9	1.18
5	MAY 12 - MAY 25	1.0	0.93
6	MAY 26 - JUN 8	0.8	1.06
7	JUN 9 - JUN 22	0.8	0.98
8	JUN 23 - JUL 6	0.9	0.95
9	JUL 7 - JUL 20	0.7	1.03
10	JUL 21 - AUG 3	0.7	0.94
11	AUG 4 - AUG 17	0.8	0.93
12	AUG 18 - AUG 31	0.9	0.92
13	SEP 1 - SEP 14	0.8	1.11
14	SEP 15 - SEP 28	0.8	1.16
15	SEP 29 - OCT 12	0.8	1.14
16	OCT 13 - OCT 26	0.9	1.01
17	OCT 27 - NOV 9	0.9	1.12
18	NOV 10 - NOV 23	0.9	1.15
19	NOV 24 - DEC 7	1.0	0.88
20	DEC 8 - DEC 21	0.8	1.06
21	DEC 22 - JAN 4	0.8	0.94
22	JAN 5 - JAN 18	0.8	1.06
23	JAN 19 - FEB 1	0.8	1.01
24	FEB 2 - FEB 15	0.8	1.19
25	FEB 16 - FEB 29	0.8	0.94
26	MAR 1 - MAR 14	0.8	1.01
27	MAR 15 - MAR 28	0.8	1.08

Summary for BINSCARTH		
Average	0.8	1.03
Minimum	0.7	0.88
Maximum	1.0	1.19
Samples Above Limit	0	
Samples Below Limits	2	
% Outside Limits:	7%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION BIRTLE
OPERATOR Darwin Fleury
PHONE 842-3234

FLUORIDATOR LMI A741
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.26

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.8	1.10
2	MAR 31 - APR 13	0.5	1.00
3	APR 14 - APR 27	1.0	1.60
4	APR 28 - MAY 11	NOT AVAILABLE	NOT AVAILABLE
5	MAY 12 - MAY 25	NOT AVAILABLE	NOT AVAILABLE
6	MAY 26 - JUN 8	NOT AVAILABLE	NOT AVAILABLE
7	JUN 9 - JUN 22	NOT AVAILABLE	NOT AVAILABLE
8	JUN 23 - JUL 6	NOT AVAILABLE	NOT AVAILABLE
9	JUL 7 - JUL 20	NOT AVAILABLE	NOT AVAILABLE
10	JUL 21 - AUG 3	NOT AVAILABLE	NOT AVAILABLE
11	AUG 4 - AUG 17	NOT AVAILABLE	NOT AVAILABLE
12	AUG 18 - AUG 31	NOT AVAILABLE	NOT AVAILABLE
13	SEP 1 - SEP 14	NOT AVAILABLE	NOT AVAILABLE
14	SEP 15 - SEP 28	NOT AVAILABLE	NOT AVAILABLE
15	SEP 29 - OCT 12	NOT AVAILABLE	NOT AVAILABLE
16	OCT 13 - OCT 26	NOT AVAILABLE	NOT AVAILABLE
17	OCT 27 - NOV 9	NOT AVAILABLE	NOT AVAILABLE
18	NOV 10 - NOV 23	NOT AVAILABLE	NOT AVAILABLE
19	NOV 24 - DEC 7	NOT AVAILABLE	NOT AVAILABLE
20	DEC 8 - DEC 21	NOT AVAILABLE	NOT AVAILABLE
21	DEC 22 - JAN 4	NOT AVAILABLE	NOT AVAILABLE
22	JAN 5 - JAN 18	NOT AVAILABLE	NOT AVAILABLE
23	JAN 19 - FEB 1	NOT AVAILABLE	NOT AVAILABLE
24	FEB 2 - FEB 15	NOT AVAILABLE	NOT AVAILABLE
25	FEB 16 - FEB 29	NOT AVAILABLE	NOT AVAILABLE
26	MAR 1 - MAR 14	NOT AVAILABLE	NOT AVAILABLE
27	MAR 15 - MAR 28	NOT AVAILABLE	NOT AVAILABLE

Summary for BIRTLE

Average	0.8	1.23
Minimum	0.5	1.00
Maximum	1.0	1.60
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	33%	
Number of Samples	3	

Fluoride Control Data 2007 / 2008

LOCATION	BOISSEVAIN	FLUORIDATOR	Precision
OPERATOR	Barry Chinner	CHEMICAL	NaF 4 %
PHONE	534-2433	NATURAL FLUORIDE	0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.09
2	MAR 31 - APR 13	1.0	0.98
3	APR 14 - APR 27	0.9	1.13
4	APR 28 - MAY 11	1.0	1.08
5	MAY 12 - MAY 25	1.1	1.14
6	MAY 26 - JUN 8	1.0	1.06
7	JUN 9 - JUN 22	0.9	1.02
8	JUN 23 - JUL 6	1.0	1.05
9	JUL 7 - JUL 20	0.9	1.15
10	JUL 21 - AUG 3	0.9	1.03
11	AUG 4 - AUG 17	1.0	1.12
12	AUG 18 - AUG 31	1.0	0.93
13	SEP 1 - SEP 14	1.1	1.12
14	SEP 15 - SEP 28	1.0	1.08
15	SEP 29 - OCT 12	1.1	1.10
16	OCT 13 - OCT 26	1.1	1.11
17	OCT 27 - NOV 9	1.1	1.03
18	NOV 10 - NOV 23	1.1	1.08
19	NOV 24 - DEC 7	1.1	1.10
20	DEC 8 - DEC 21	1.2	0.93
21	DEC 22 - JAN 4	1.0	0.99
22	JAN 5 - JAN 18	0.9	1.03
23	JAN 19 - FEB 1	1.0	1.06
24	FEB 2 - FEB 15	1.0	1.12
25	FEB 16 - FEB 29	1.0	1.07
26	MAR 1 - MAR 14	1.0	1.06
27	MAR 15 - MAR 28	1.0	1.06

Summary for BOISSEVAIN		
Average	1.0	1.06
Minimum	0.9	0.93
Maximum	1.2	1.15
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	BRANDON	FLUORIDATOR	W&T A690
OPERATOR	Brad McIntosh	CHEMICAL	Na2SiF6 (Dry)
PHONE	729-2190	NATURAL FLUORIDE	0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	1.06
2	MAR 31 - APR 13	0.9	0.96
3	APR 14 - APR 27	1.2	1.03
4	APR 28 - MAY 11	1.2	1.11
5	MAY 12 - MAY 25	1.2	1.10
6	MAY 26 - JUN 8	1.2	1.17
7	JUN 9 - JUN 22	0.9	0.97
8	JUN 23 - JUL 6	1.1	1.14
9	JUL 7 - JUL 20	1.0	1.06
10	JUL 21 - AUG 3	1.0	1.01
11	AUG 4 - AUG 17	1.0	1.03
12	AUG 18 - AUG 31	1.0	1.49
13	SEP 1 - SEP 14	0.9	0.92
14	SEP 15 - SEP 28	1.1	1.05
15	SEP 29 - OCT 12	1.1	1.20
16	OCT 13 - OCT 26	1.2	1.08
17	OCT 27 - NOV 9	1.3	1.14
18	NOV 10 - NOV 23	1.2	1.09
19	NOV 24 - DEC 7	0.7	0.46
20	DEC 8 - DEC 21	NOT AVAILABLE	NOT AVAILABLE
21	DEC 22 - JAN 4	1.2	1.01
22	JAN 5 - JAN 18	1.3	1.14
23	JAN 19 - FEB 1	1.2	1.33
24	FEB 2 - FEB 15	1.1	1.01
25	FEB 16 - FEB 29	1.1	1.06
26	MAR 1 - MAR 14	1.2	1.04
27	MAR 15 - MAR 28	1.2	1.20

Summary for BRANDON		
Average	1.1	1.07
Minimum	0.7	0.46
Maximum	1.3	1.49
Samples Above Limit	2	
Samples Below Limits	1	
% Outside Limits:	12%	
Number of Samples	26	

Fluoride Control Data 2007 / 2008

LOCATION	CARMAN	FLUORIDATOR	W&T 47-050
OPERATOR	Bob Lambert	CHEMICAL	H2SiF6 25 %
PHONE	745-2481	NATURAL FLUORIDE	0.21

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.00
2	MAR 31 - APR 13	1.1	1.16
3	APR 14 - APR 27	1.2	1.28
4	APR 28 - MAY 11	1.1	1.08
5	MAY 12 - MAY 25	1.0	1.05
6	MAY 26 - JUN 8	1.2	0.94
7	JUN 9 - JUN 22	1.3	1.07
8	JUN 23 - JUL 6	1.2	1.22
9	JUL 7 - JUL 20	1.0	1.24
10	JUL 21 - AUG 3	1.0	0.97
11	AUG 4 - AUG 17	1.0	0.94
12	AUG 18 - AUG 31	1.1	1.04
13	SEP 1 - SEP 14	1.2	0.88
14	SEP 15 - SEP 28	1.2	1.01
15	SEP 29 - OCT 12	1.2	0.91
16	OCT 13 - OCT 26	0.9	0.87
17	OCT 27 - NOV 9	0.9	0.89
18	NOV 10 - NOV 23	1.0	1.01
19	NOV 24 - DEC 7	1.0	0.98
20	DEC 8 - DEC 21	1.0	0.86
21	DEC 22 - JAN 4	0.9	0.77
22	JAN 5 - JAN 18	0.9	0.79
23	JAN 19 - FEB 1	1.0	1.01
24	FEB 2 - FEB 15	1.0	0.98
25	FEB 16 - FEB 29	1.0	0.99
26	MAR 1 - MAR 14	1.1	1.05
27	MAR 15 - MAR 28	1.0	0.68

Summary for CARMAN		
Average	1.1	0.99
Minimum	0.9	0.68
Maximum	1.3	1.28
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION CARTIER REGIONAL	FLUORIDATOR N/A
OPERATOR Dave Pirt	CHEMICAL H2SiF6 25 %
PHONE 353-4055	NATURAL FLUORIDE N/A

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	1.00
2	MAR 31 - APR 13	1.9	1.10
3	APR 14 - APR 27	1.0	1.20
4	APR 28 - MAY 11	1.0	1.10
5	MAY 12 - MAY 25	1.1	1.30
6	MAY 26 - JUN 8	1.0	1.40
7	JUN 9 - JUN 22	0.9	1.20
8	JUN 23 - JUL 6	0.9	1.10
9	JUL 7 - JUL 20	0.9	1.20
10	JUL 21 - AUG 3	1.0	1.10
11	AUG 4 - AUG 17	0.8	1.00
12	AUG 18 - AUG 31	1.1	1.00
13	SEP 1 - SEP 14	1.1	1.00
14	SEP 15 - SEP 28	1.2	1.10
15	SEP 29 - OCT 12	1.1	1.00
16	OCT 13 - OCT 26	1.0	1.00
17	OCT 27 - NOV 9	1.1	0.90
18	NOV 10 - NOV 23	1.2	1.00
19	NOV 24 - DEC 7	1.2	0.00
20	DEC 8 - DEC 21	1.1	1.00
21	DEC 22 - JAN 4	0.9	1.20
22	JAN 5 - JAN 18	0.8	1.20
23	JAN 19 - FEB 1	0.8	1.10
24	FEB 2 - FEB 15	0.7	1.10
25	FEB 16 - FEB 29	0.6	1.00
26	MAR 1 - MAR 14	1.0	0.90
27	MAR 15 - MAR 28	0.7	1.00

Summary for CARTIER REGIONAL

Average	1.0	1.04
Minimum	0.6	0.00
Maximum	1.9	1.40
Samples Above Limit	1	
Samples Below Limits	3	
% Outside Limits:	15%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION CHURCHILL
OPERATOR William Ayotte
PHONE 675-8871

FLUORIDATOR Prom Gamma
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE < 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.00
2	MAR 31 - APR 13	0.9	1.00
3	APR 14 - APR 27	1.0	0.90
4	APR 28 - MAY 11	1.0	1.00
5	MAY 12 - MAY 25	1.0	1.00
6	MAY 26 - JUN 8	1.0	0.80
7	JUN 9 - JUN 22	1.0	1.00
8	JUN 23 - JUL 6	1.1	1.10
9	JUL 7 - JUL 20	1.0	NOT AVAILABLE
10	JUL 21 - AUG 3	0.9	1.20
11	AUG 4 - AUG 17	0.9	1.00
12	AUG 18 - AUG 31	0.9	1.10
13	SEP 1 - SEP 14	0.9	0.90
14	SEP 15 - SEP 28	0.9	1.00
15	SEP 29 - OCT 12	1.0	1.00
16	OCT 13 - OCT 26	0.9	1.20
17	OCT 27 - NOV 9	0.9	1.00
18	NOV 10 - NOV 23	1.0	1.00
19	NOV 24 - DEC 7	0.9	0.90
20	DEC 8 - DEC 21	0.8	0.60
21	DEC 22 - JAN 4	1.1	0.90
22	JAN 5 - JAN 18	1.2	0.90
23	JAN 19 - FEB 1	1.0	0.90
24	FEB 2 - FEB 15	1.2	1.10
25	FEB 16 - FEB 29	1.1	0.00
26	MAR 1 - MAR 14	1.2	1.00
27	MAR 15 - MAR 28	1.2	0.00

Summary for CHURCHILL

Average	1.0	0.90
Minimum	0.8	0.00
Maximum	1.2	1.20
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION CRANBERRY PORTAGE
OPERATOR Darcy Rajczakowski
PHONE 472-6321

FLUORIDATOR LMI A151
CHEMICAL NaF 4 %
NATURAL FLUORIDE < 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	NOT AVAILABLE
2	MAR 31 - APR 13	1.3	NOT AVAILABLE
3	APR 14 - APR 27	1.1	NOT AVAILABLE
4	APR 28 - MAY 11	1.2	NOT AVAILABLE
5	MAY 12 - MAY 25	1.1	NOT AVAILABLE
6	MAY 26 - JUN 8	1.1	NOT AVAILABLE
7	JUN 9 - JUN 22	1.1	NOT AVAILABLE
8	JUN 23 - JUL 6	1.1	NOT AVAILABLE
9	JUL 7 - JUL 20	1.0	NOT AVAILABLE
10	JUL 21 - AUG 3	1.0	NOT AVAILABLE
11	AUG 4 - AUG 17	1.1	NOT AVAILABLE
12	AUG 18 - AUG 31	1.3	NOT AVAILABLE
13	SEP 1 - SEP 14	1.4	NOT AVAILABLE
14	SEP 15 - SEP 28	1.4	1.00
15	SEP 29 - OCT 12	1.3	0.00
16	OCT 13 - OCT 26	1.3	0.00
17	OCT 27 - NOV 9	1.3	0.00
18	NOV 10 - NOV 23	1.6	0.00
19	NOV 24 - DEC 7	1.0	0.00
20	DEC 8 - DEC 21	1.1	0.00
21	DEC 22 - JAN 4	1.1	0.00
22	JAN 5 - JAN 18	1.1	0.91
23	JAN 19 - FEB 1	1.0	1.10
24	FEB 2 - FEB 15	1.2	0.96
25	FEB 16 - FEB 29	1.2	0.00
26	MAR 1 - MAR 14	1.1	0.00
27	MAR 15 - MAR 28	1.0	1.03

Summary for CRANBERRY PORTAGE

Average	1.2	0.36
Minimum	1.0	0.00
Maximum	1.6	1.10
Samples Above Limit	8	
Samples Below Limits	0	
% Outside Limits:	30%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	CROSS LAKE RESERVE	FLUORIDATOR	LMI Saturator
OPERATOR	Lawrence McLeod	CHEMICAL	NaF 4 %
PHONE	676-2044	NATURAL FLUORIDE	< 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	1.00
2	MAR 31 - APR 13	1.0	0.90
3	APR 14 - APR 27	1.2	1.20
4	APR 28 - MAY 11	1.0	0.80
5	MAY 12 - MAY 25	1.0	1.00
6	MAY 26 - JUN 8	1.0	0.80
7	JUN 9 - JUN 22	0.5	0.70
8	JUN 23 - JUL 6	0.8	0.70
9	JUL 7 - JUL 20	0.7	0.80
10	JUL 21 - AUG 3	1.2	1.20
11	AUG 4 - AUG 17	1.1	1.10
12	AUG 18 - AUG 31	0.8	0.80
13	SEP 1 - SEP 14	1.1	0.90
14	SEP 15 - SEP 28	1.0	0.70
15	SEP 29 - OCT 12	1.3	1.00
16	OCT 13 - OCT 26	0.9	0.90
17	OCT 27 - NOV 9	1.4	0.90
18	NOV 10 - NOV 23	1.2	1.40
19	NOV 24 - DEC 7	1.3	1.00
20	DEC 8 - DEC 21	0.9	0.00
21	DEC 22 - JAN 4	0.6	0.00
22	JAN 5 - JAN 18	1.0	0.80
23	JAN 19 - FEB 1	1.0	0.90
24	FEB 2 - FEB 15	0.9	0.80
25	FEB 16 - FEB 29	1.1	1.00
26	MAR 1 - MAR 14	1.3	0.90
27	MAR 15 - MAR 28	1.1	0.80

Summary for CROSS LAKE RESERVE

Average	1.0	0.85
Minimum	0.5	0.00
Maximum	1.4	1.40
Samples Above Limit	4	
Samples Below Limits	3	
% Outside Limits:	26%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION DAUPHIN
OPERATOR Bill Brenner
PHONE 622-3200

FLUORIDATOR W&T A690 Pa
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.14

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	1.02
2	MAR 31 - APR 13	1.1	0.96
3	APR 14 - APR 27	1.1	1.05
4	APR 28 - MAY 11	1.1	1.14
5	MAY 12 - MAY 25	1.2	1.08
6	MAY 26 - JUN 8	1.1	1.06
7	JUN 9 - JUN 22	1.0	1.22
8	JUN 23 - JUL 6	1.1	0.98
9	JUL 7 - JUL 20	1.0	1.07
10	JUL 21 - AUG 3	1.0	1.03
11	AUG 4 - AUG 17	1.1	1.17
12	AUG 18 - AUG 31	1.0	1.18
13	SEP 1 - SEP 14	1.2	1.11
14	SEP 15 - SEP 28	1.2	0.98
15	SEP 29 - OCT 12	1.2	1.03
16	OCT 13 - OCT 26	1.2	1.05
17	OCT 27 - NOV 9	1.2	1.08
18	NOV 10 - NOV 23	1.3	1.13
19	NOV 24 - DEC 7	1.3	1.07
20	DEC 8 - DEC 21	1.3	1.15
21	DEC 22 - JAN 4	1.1	1.08
22	JAN 5 - JAN 18	1.1	1.02
23	JAN 19 - FEB 1	1.0	1.12
24	FEB 2 - FEB 15	1.0	1.06
25	FEB 16 - FEB 29	1.0	1.04
26	MAR 1 - MAR 14	1.0	1.21
27	MAR 15 - MAR 28	1.1	1.07

Summary for DAUPHIN

Average	1.1	1.08
Minimum	1.0	0.96
Maximum	1.3	1.22
Samples Above Limit	3	
Samples Below Limits	0	
% Outside Limits:	11%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION DELORAINE
OPERATOR Kent Corkish
PHONE 747-2655

FLUORIDATOR LMI Saturator
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.16

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.06
2	MAR 31 - APR 13	1.1	1.18
3	APR 14 - APR 27	0.9	1.11
4	APR 28 - MAY 11	0.9	1.04
5	MAY 12 - MAY 25	1.0	1.08
6	MAY 26 - JUN 8	1.0	1.14
7	JUN 9 - JUN 22	0.9	1.08
8	JUN 23 - JUL 6	0.9	1.09
9	JUL 7 - JUL 20	0.9	1.15
10	JUL 21 - AUG 3	0.9	1.10
11	AUG 4 - AUG 17	1.0	1.14
12	AUG 18 - AUG 31	0.9	1.06
13	SEP 1 - SEP 14	1.0	1.06
14	SEP 15 - SEP 28	1.1	1.08
15	SEP 29 - OCT 12	1.0	1.15
16	OCT 13 - OCT 26	1.1	1.07
17	OCT 27 - NOV 9	1.1	1.16
18	NOV 10 - NOV 23	1.1	1.15
19	NOV 24 - DEC 7	1.1	1.16
20	DEC 8 - DEC 21	1.2	1.15
21	DEC 22 - JAN 4	1.0	1.08
22	JAN 5 - JAN 18	1.0	1.08
23	JAN 19 - FEB 1	1.0	1.10
24	FEB 2 - FEB 15	1.0	1.06
25	FEB 16 - FEB 29	1.0	1.10
26	MAR 1 - MAR 14	1.1	1.09
27	MAR 15 - MAR 28	1.0	1.08

Summary for DELORAINE		
Average	1.0	1.10
Minimum	0.9	1.04
Maximum	1.2	1.18
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	FLIN FLON	FLUORIDATOR	Prominent
OPERATOR	Kevin Komarnicki	CHEMICAL	H2SiF6 25 %
PHONE	681-7511	NATURAL FLUORIDE	< 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	1.01
2	MAR 31 - APR 13	1.0	0.92
3	APR 14 - APR 27	1.0	0.98
4	APR 28 - MAY 11	1.2	1.03
5	MAY 12 - MAY 25	1.1	1.05
6	MAY 26 - JUN 8	1.0	0.99
7	JUN 9 - JUN 22	0.9	0.84
8	JUN 23 - JUL 6	1.0	0.87
9	JUL 7 - JUL 20	0.8	1.18
10	JUL 21 - AUG 3	0.9	0.95
11	AUG 4 - AUG 17	1.1	1.06
12	AUG 18 - AUG 31	1.0	0.99
13	SEP 1 - SEP 14	1.1	1.01
14	SEP 15 - SEP 28	1.1	0.96
15	SEP 29 - OCT 12	1.2	1.03
16	OCT 13 - OCT 26	1.1	1.01
17	OCT 27 - NOV 9	1.2	1.06
18	NOV 10 - NOV 23	1.2	0.90
19	NOV 24 - DEC 7	1.2	0.97
20	DEC 8 - DEC 21	1.4	1.16
21	DEC 22 - JAN 4	1.0	0.96
22	JAN 5 - JAN 18	1.0	1.04
23	JAN 19 - FEB 1	0.9	0.93
24	FEB 2 - FEB 15	0.9	0.85
25	FEB 16 - FEB 29	1.1	0.93
26	MAR 1 - MAR 14	1.0	1.05
27	MAR 15 - MAR 28	1.0	0.82

Summary for FLIN FLON		
Average	1.1	0.98
Minimum	0.8	0.82
Maximum	1.4	1.18
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION GILBERT PLAINS
OPERATOR Lloyd Beckley
PHONE 548-2149

FLUORIDATOR LMI A741
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.7	0.88
2	MAR 31 - APR 13	0.7	0.70
3	APR 14 - APR 27	0.5	0.50
4	APR 28 - MAY 11	0.7	0.75
5	MAY 12 - MAY 25	0.9	0.90
6	MAY 26 - JUN 8	0.9	0.87
7	JUN 9 - JUN 22	0.8	0.80
8	JUN 23 - JUL 6	1.0	0.90
9	JUL 7 - JUL 20	1.0	0.90
10	JUL 21 - AUG 3	0.6	0.70
11	AUG 4 - AUG 17	0.8	0.80
12	AUG 18 - AUG 31	0.9	1.02
13	SEP 1 - SEP 14	0.6	0.70
14	SEP 15 - SEP 28	1.0	0.90
15	SEP 29 - OCT 12	1.0	0.95
16	OCT 13 - OCT 26	1.0	1.00
17	OCT 27 - NOV 9	0.9	0.90
18	NOV 10 - NOV 23	0.9	0.00
19	NOV 24 - DEC 7	0.8	0.85
20	DEC 8 - DEC 21	0.6	0.75
21	DEC 22 - JAN 4	0.9	1.02
22	JAN 5 - JAN 18	0.9	1.00
23	JAN 19 - FEB 1	0.8	0.95
24	FEB 2 - FEB 15	0.8	0.95
25	FEB 16 - FEB 29	0.8	0.90
26	MAR 1 - MAR 14	0.8	0.00
27	MAR 15 - MAR 28	0.7	0.65

Summary for GILBERT PLAINS

Average	0.8	0.79
Minimum	0.5	0.00
Maximum	1.0	1.02
Samples Above Limit	0	
Samples Below Limits	8	
% Outside Limits:	30%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION GILLAM
OPERATOR John McDonald
PHONE 652-2121

FLUORIDATOR W&T
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE < 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	1.23
2	MAR 31 - APR 13	1.1	1.24
3	APR 14 - APR 27	1.1	1.29
4	APR 28 - MAY 11	1.2	1.50
5	MAY 12 - MAY 25	1.2	1.29
6	MAY 26 - JUN 8	1.1	0.72
7	JUN 9 - JUN 22	1.1	1.02
8	JUN 23 - JUL 6	1.2	1.06
9	JUL 7 - JUL 20	1.1	0.93
10	JUL 21 - AUG 3	1.0	1.60
11	AUG 4 - AUG 17	1.0	1.04
12	AUG 18 - AUG 31	1.0	0.99
13	SEP 1 - SEP 14	1.2	0.97
14	SEP 15 - SEP 28	1.2	0.96
15	SEP 29 - OCT 12	1.2	1.03
16	OCT 13 - OCT 26	1.2	0.93
17	OCT 27 - NOV 9	0.8	0.24
18	NOV 10 - NOV 23	2.4	1.54
19	NOV 24 - DEC 7	1.9	1.65
20	DEC 8 - DEC 21	1.4	0.87
21	DEC 22 - JAN 4	1.2	1.00
22	JAN 5 - JAN 18	1.1	0.00
23	JAN 19 - FEB 1	1.0	0.93
24	FEB 2 - FEB 15	1.0	0.00
25	FEB 16 - FEB 29	1.1	0.78
26	MAR 1 - MAR 14	1.0	0.99
27	MAR 15 - MAR 28	1.2	0.99

Summary for GILLAM

Average	1.2	0.99
Minimum	0.8	0.00
Maximum	2.4	1.65
Samples Above Limit	3	
Samples Below Limits	0	
% Outside Limits:	11%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION GIMLI INDUSTRIAL PARK
OPERATOR Richard Bezdietny
PHONE 642-8593

FLUORIDATOR W&T A747
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.43

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.03
2	MAR 31 - APR 13	0.9	0.90
3	APR 14 - APR 27	1.0	1.00
4	APR 28 - MAY 11	1.2	1.01
5	MAY 12 - MAY 25	1.2	1.03
6	MAY 26 - JUN 8	1.2	1.05
7	JUN 9 - JUN 22	1.1	1.12
8	JUN 23 - JUL 6	1.0	0.90
9	JUL 7 - JUL 20	0.9	0.97
10	JUL 21 - AUG 3	1.1	1.13
11	AUG 4 - AUG 17	1.1	1.06
12	AUG 18 - AUG 31	0.9	0.92
13	SEP 1 - SEP 14	1.1	1.00
14	SEP 15 - SEP 28	1.3	1.10
15	SEP 29 - OCT 12	1.2	1.08
16	OCT 13 - OCT 26	1.2	1.08
17	OCT 27 - NOV 9	1.0	0.90
18	NOV 10 - NOV 23	1.1	1.00
19	NOV 24 - DEC 7	0.9	0.90
20	DEC 8 - DEC 21	1.3	0.99
21	DEC 22 - JAN 4	1.1	1.10
22	JAN 5 - JAN 18	1.0	1.05
23	JAN 19 - FEB 1	1.0	1.00
24	FEB 2 - FEB 15	1.0	1.07
25	FEB 16 - FEB 29	1.0	1.04
26	MAR 1 - MAR 14	0.9	0.92
27	MAR 15 - MAR 28	1.0	1.05

Summary for GIMLI INDUSTRIAL PARK

Average	1.1	1.01
Minimum	0.9	0.90
Maximum	1.3	1.13
Samples Above Limit	2	
Samples Below Limits	0	
% Outside Limits:	7%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION GRISWOLD SIOUX VALLEY BAND
OPERATOR Avin Dowan
PHONE 855-2690

FLUORIDATOR N/A
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.1

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	NOT AVAILABLE	NOT AVAILABLE
2	MAR 31 - APR 13	NOT AVAILABLE	NOT AVAILABLE
3	APR 14 - APR 27	1.0	NOT AVAILABLE
4	APR 28 - MAY 11	NOT AVAILABLE	NOT AVAILABLE
5	MAY 12 - MAY 25	1.0	NOT AVAILABLE
6	MAY 26 - JUN 8	NOT AVAILABLE	NOT AVAILABLE
7	JUN 9 - JUN 22	NOT AVAILABLE	NOT AVAILABLE
8	JUN 23 - JUL 6	0.5	NOT AVAILABLE
9	JUL 7 - JUL 20	0.4	NOT AVAILABLE
10	JUL 21 - AUG 3	0.7	NOT AVAILABLE
11	AUG 4 - AUG 17	0.8	NOT AVAILABLE
12	AUG 18 - AUG 31	0.7	NOT AVAILABLE
13	SEP 1 - SEP 14	NOT AVAILABLE	NOT AVAILABLE
14	SEP 15 - SEP 28	1.0	NOT AVAILABLE
15	SEP 29 - OCT 12	0.8	0.00
16	OCT 13 - OCT 26	NOT AVAILABLE	NOT AVAILABLE
17	OCT 27 - NOV 9	1.1	0.00
18	NOV 10 - NOV 23	0.8	0.00
19	NOV 24 - DEC 7	1.3	0.00
20	DEC 8 - DEC 21	NOT AVAILABLE	NOT AVAILABLE
21	DEC 22 - JAN 4	NOT AVAILABLE	NOT AVAILABLE
22	JAN 5 - JAN 18	0.8	0.00
23	JAN 19 - FEB 1	NOT AVAILABLE	NOT AVAILABLE
24	FEB 2 - FEB 15	NOT AVAILABLE	NOT AVAILABLE
25	FEB 16 - FEB 29	NOT AVAILABLE	NOT AVAILABLE
26	MAR 1 - MAR 14	NOT AVAILABLE	NOT AVAILABLE
27	MAR 15 - MAR 28	NOT AVAILABLE	NOT AVAILABLE

Summary for GRISWOLD SIOUX VALLEY BAND

Average	0.8	0.00
Minimum	0.4	0.00
Maximum	1.3	0.00
Samples Above Limit	1	
Samples Below Limits	4	
% Outside Limits:	38%	
Number of Samples	13	

Fluoride Control Data 2007 / 2008

LOCATION HAMIOTA
OPERATOR Ken Curle
PHONE 764-2779

FLUORIDATOR LMI A751
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.29

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.8	0.82
2	MAR 31 - APR 13	1.5	1.39
3	APR 14 - APR 27	1.7	0.82
4	APR 28 - MAY 11	1.2	0.88
5	MAY 12 - MAY 25	1.0	0.99
6	MAY 26 - JUN 8	1.0	0.74
7	JUN 9 - JUN 22	0.9	0.85
8	JUN 23 - JUL 6	0.9	0.75
9	JUL 7 - JUL 20	0.8	0.98
10	JUL 21 - AUG 3	0.8	1.04
11	AUG 4 - AUG 17	0.8	0.80
12	AUG 18 - AUG 31	0.9	0.95
13	SEP 1 - SEP 14	1.1	0.91
14	SEP 15 - SEP 28	1.1	0.94
15	SEP 29 - OCT 12	1.1	0.99
16	OCT 13 - OCT 26	1.1	0.94
17	OCT 27 - NOV 9	1.0	0.90
18	NOV 10 - NOV 23	1.2	0.89
19	NOV 24 - DEC 7	1.1	1.01
20	DEC 8 - DEC 21	1.3	1.02
21	DEC 22 - JAN 4	1.2	1.16
22	JAN 5 - JAN 18	1.1	0.98
23	JAN 19 - FEB 1	0.9	0.86
24	FEB 2 - FEB 15	1.5	1.57
25	FEB 16 - FEB 29	1.0	1.26
26	MAR 1 - MAR 14	1.0	0.76
27	MAR 15 - MAR 28	1.1	0.98

Summary for HAMIOTA

Average	1.1	0.97
Minimum	0.8	0.74
Maximum	1.7	1.57
Samples Above Limit	4	
Samples Below Limits	0	
% Outside Limits:	15%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION HARTNEY
OPERATOR Greg Morrison
PHONE 858-2429

FLUORIDATOR LMI A741
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	2.3	0.83
2	MAR 31 - APR 13	2.3	0.86
3	APR 14 - APR 27	1.9	1.50
4	APR 28 - MAY 11	1.2	1.06
5	MAY 12 - MAY 25	1.1	0.87
6	MAY 26 - JUN 8	1.1	0.98
7	JUN 9 - JUN 22	1.0	0.98
8	JUN 23 - JUL 6	1.2	1.05
9	JUL 7 - JUL 20	1.2	0.97
10	JUL 21 - AUG 3	1.1	1.15
11	AUG 4 - AUG 17	1.2	1.17
12	AUG 18 - AUG 31	0.9	0.91
13	SEP 1 - SEP 14	1.5	1.18
14	SEP 15 - SEP 28	1.0	0.95
15	SEP 29 - OCT 12	1.0	0.85
16	OCT 13 - OCT 26	1.0	0.99
17	OCT 27 - NOV 9	1.2	1.02
18	NOV 10 - NOV 23	1.4	1.19
19	NOV 24 - DEC 7	1.2	1.11
20	DEC 8 - DEC 21	1.4	1.20
21	DEC 22 - JAN 4	1.0	0.95
22	JAN 5 - JAN 18	0.8	1.01
23	JAN 19 - FEB 1	0.8	0.89
24	FEB 2 - FEB 15	1.0	0.99
25	FEB 16 - FEB 29	1.0	1.06
26	MAR 1 - MAR 14	1.0	0.85
27	MAR 15 - MAR 28	1.1	1.08

Summary for HARTNEY

Average	1.2	1.02
Minimum	0.8	0.83
Maximum	2.3	1.50
Samples Above Limit	6	
Samples Below Limits	0	
% Outside Limits:	22%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	KILLARNEY	FLUORIDATOR	LMI B721
OPERATOR	Shawn Lamb	CHEMICAL	NaF 4 %
PHONE	523-8944	NATURAL FLUORIDE	0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.8	1.56
2	MAR 31 - APR 13	0.3	1.09
3	APR 14 - APR 27	0.8	1.03
4	APR 28 - MAY 11	0.7	1.32
5	MAY 12 - MAY 25	1.1	1.65
6	MAY 26 - JUN 8	1.6	1.88
7	JUN 9 - JUN 22	1.7	1.98
8	JUN 23 - JUL 6	1.4	1.79
9	JUL 7 - JUL 20	1.5	1.84
10	JUL 21 - AUG 3	1.1	1.66
11	AUG 4 - AUG 17	1.2	1.67
12	AUG 18 - AUG 31	1.4	1.67
13	SEP 1 - SEP 14	1.8	1.68
14	SEP 15 - SEP 28	1.9	1.64
15	SEP 29 - OCT 12	1.1	1.66
16	OCT 13 - OCT 26	1.3	1.78
17	OCT 27 - NOV 9	1.1	1.68
18	NOV 10 - NOV 23	1.0	1.39
19	NOV 24 - DEC 7	1.1	1.34
20	DEC 8 - DEC 21	1.0	1.43
21	DEC 22 - JAN 4	1.0	1.51
22	JAN 5 - JAN 18	0.9	1.02
23	JAN 19 - FEB 1	0.8	1.02
24	FEB 2 - FEB 15	1.1	1.21
25	FEB 16 - FEB 29	1.2	1.30
26	MAR 1 - MAR 14	1.0	1.29
27	MAR 15 - MAR 28	1.3	1.53

Summary for KILLARNEY

Average	1.2	1.50
Minimum	0.3	1.02
Maximum	1.9	1.98
Samples Above Limit	9	
Samples Below Limits	2	
% Outside Limits:	41%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION LETELLIER-RRRWTP
OPERATOR Kurt Henry
PHONE 737-2265

FLUORIDATOR LMI
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.17

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	1.11
2	MAR 31 - APR 13	1.0	1.13
3	APR 14 - APR 27	1.0	1.01
4	APR 28 - MAY 11	1.1	0.97
5	MAY 12 - MAY 25	1.2	1.05
6	MAY 26 - JUN 8	1.2	1.15
7	JUN 9 - JUN 22	1.1	1.08
8	JUN 23 - JUL 6	1.2	1.06
9	JUL 7 - JUL 20	1.1	1.14
10	JUL 21 - AUG 3	1.0	1.05
11	AUG 4 - AUG 17	1.0	1.10
12	AUG 18 - AUG 31	1.1	1.15
13	SEP 1 - SEP 14	1.2	1.11
14	SEP 15 - SEP 28	1.2	1.09
15	SEP 29 - OCT 12	1.2	1.17
16	OCT 13 - OCT 26	1.2	1.20
17	OCT 27 - NOV 9	1.2	1.15
18	NOV 10 - NOV 23	0.8	0.88
19	NOV 24 - DEC 7	0.9	0.94
20	DEC 8 - DEC 21	1.0	0.96
21	DEC 22 - JAN 4	0.9	0.89
22	JAN 5 - JAN 18	0.8	0.92
23	JAN 19 - FEB 1	0.8	1.01
24	FEB 2 - FEB 15	0.8	1.02
25	FEB 16 - FEB 29	0.8	0.96
26	MAR 1 - MAR 14	0.9	0.99
27	MAR 15 - MAR 28	0.7	0.00

Summary for LETELLIER-RRRWTP

Average	1.0	1.01
Minimum	0.7	0.00
Maximum	1.2	1.20
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	4%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	LONG PLAIN	FLUORIDATOR	LMI Saturator
OPERATOR	Morris Peters	CHEMICAL	NaF 4 %
PHONE	252-2094	NATURAL FLUORIDE	0.23

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.2	0.79
2	MAR 31 - APR 13	NOT AVAILABLE	NOT AVAILABLE
3	APR 14 - APR 27	1.0	0.62
4	APR 28 - MAY 11	1.0	0.84
5	MAY 12 - MAY 25	1.1	NOT AVAILABLE
6	MAY 26 - JUN 8	1.1	0.97
7	JUN 9 - JUN 22	1.0	0.70
8	JUN 23 - JUL 6	0.9	0.65
9	JUL 7 - JUL 20	1.1	0.95
10	JUL 21 - AUG 3	0.9	0.77
11	AUG 4 - AUG 17	0.7	0.56
12	AUG 18 - AUG 31	0.8	1.13
13	SEP 1 - SEP 14	1.1	1.11
14	SEP 15 - SEP 28	1.0	0.85
15	SEP 29 - OCT 12	1.1	1.04
16	OCT 13 - OCT 26	0.9	0.95
17	OCT 27 - NOV 9	1.1	0.93
18	NOV 10 - NOV 23	0.7	0.56
19	NOV 24 - DEC 7	0.8	0.60
20	DEC 8 - DEC 21	1.5	0.00
21	DEC 22 - JAN 4	1.2	0.93
22	JAN 5 - JAN 18	1.0	1.27
23	JAN 19 - FEB 1	0.8	0.79
24	FEB 2 - FEB 15	1.0	1.07
25	FEB 16 - FEB 29	1.4	0.75
26	MAR 1 - MAR 14	1.6	1.20
27	MAR 15 - MAR 28	1.5	0.70

Summary for LONG PLAIN		
Average	1.1	0.83
Minimum	0.7	0.00
Maximum	1.6	1.27
Samples Above Limit	4	
Samples Below Limits	2	
% Outside Limits:	23%	
Number of Samples	26	

Fluoride Control Data 2007 / 2008

LOCATION	MANITOU	FLUORIDATOR	LMI Saturator
OPERATOR	Keith Cowper	CHEMICAL	NaF 4 %
PHONE	242-3169	NATURAL FLUORIDE	0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.2	1.20
2	MAR 31 - APR 13	1.1	1.15
3	APR 14 - APR 27	1.1	1.13
4	APR 28 - MAY 11	1.2	1.15
5	MAY 12 - MAY 25	1.2	1.17
6	MAY 26 - JUN 8	1.1	1.09
7	JUN 9 - JUN 22	0.9	1.00
8	JUN 23 - JUL 6	0.8	0.90
9	JUL 7 - JUL 20	0.8	0.98
10	JUL 21 - AUG 3	1.1	1.25
11	AUG 4 - AUG 17	1.0	1.10
12	AUG 18 - AUG 31	0.9	1.09
13	SEP 1 - SEP 14	1.1	1.11
14	SEP 15 - SEP 28	1.0	1.08
15	SEP 29 - OCT 12	1.3	0.00
16	OCT 13 - OCT 26	1.2	1.17
17	OCT 27 - NOV 9	1.0	1.02
18	NOV 10 - NOV 23	1.2	1.15
19	NOV 24 - DEC 7	1.2	1.10
20	DEC 8 - DEC 21	1.3	1.04
21	DEC 22 - JAN 4	1.0	1.05
22	JAN 5 - JAN 18	0.9	1.12
23	JAN 19 - FEB 1	0.9	1.05
24	FEB 2 - FEB 15	0.9	1.05
25	FEB 16 - FEB 29	0.9	1.06
26	MAR 1 - MAR 14	1.0	1.05
27	MAR 15 - MAR 28	1.0	1.05

Summary for MANITOU

Average	1.0	1.05
Minimum	0.8	0.00
Maximum	1.3	1.25
Samples Above Limit	2	
Samples Below Limits	0	
% Outside Limits:	7%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	MELITA	FLUORIDATOR	W&T Saturato
OPERATOR	Bob Reddaway	CHEMICAL	NaF 4 %
PHONE	522-3413	NATURAL FLUORIDE	0.18

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	1.19
2	MAR 31 - APR 13	1.2	1.17
3	APR 14 - APR 27	1.2	1.14
4	APR 28 - MAY 11	1.2	1.17
5	MAY 12 - MAY 25	1.1	1.10
6	MAY 26 - JUN 8	1.1	1.20
7	JUN 9 - JUN 22	1.0	1.03
8	JUN 23 - JUL 6	0.9	1.04
9	JUL 7 - JUL 20	0.8	1.12
10	JUL 21 - AUG 3	0.8	1.25
11	AUG 4 - AUG 17	1.0	1.18
12	AUG 18 - AUG 31	0.8	1.26
13	SEP 1 - SEP 14	1.1	1.11
14	SEP 15 - SEP 28	1.2	1.33
15	SEP 29 - OCT 12	1.0	0.98
16	OCT 13 - OCT 26	0.6	0.69
17	OCT 27 - NOV 9	0.7	0.81
18	NOV 10 - NOV 23	0.8	0.78
19	NOV 24 - DEC 7	0.6	0.61
20	DEC 8 - DEC 21	0.7	1.01
21	DEC 22 - JAN 4	0.9	1.11
22	JAN 5 - JAN 18	0.9	0.87
23	JAN 19 - FEB 1	0.8	1.19
24	FEB 2 - FEB 15	0.7	0.92
25	FEB 16 - FEB 29	0.5	0.90
26	MAR 1 - MAR 14	0.9	1.01
27	MAR 15 - MAR 28	0.7	1.03

Summary for MELITA		
Average	0.9	1.04
Minimum	0.5	0.61
Maximum	1.2	1.33
Samples Above Limit	0	
Samples Below Limits	7	
% Outside Limits:	26%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	MINNEDOSA	FLUORIDATOR	Prominent
OPERATOR	Frank Taylor	CHEMICAL	H2SiF6 25 %
PHONE	867-2727	NATURAL FLUORIDE	0.28

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	1.18
2	MAR 31 - APR 13	0.9	1.11
3	APR 14 - APR 27	1.0	1.15
4	APR 28 - MAY 11	0.9	1.15
5	MAY 12 - MAY 25	1.0	1.18
6	MAY 26 - JUN 8	1.0	1.15
7	JUN 9 - JUN 22	0.9	1.15
8	JUN 23 - JUL 6	1.0	1.16
9	JUL 7 - JUL 20	0.8	1.19
10	JUL 21 - AUG 3	0.7	1.12
11	AUG 4 - AUG 17	0.8	1.16
12	AUG 18 - AUG 31	0.8	1.16
13	SEP 1 - SEP 14	0.8	1.20
14	SEP 15 - SEP 28	0.9	1.00
15	SEP 29 - OCT 12	NOT AVAILABLE	NOT AVAILABLE
16	OCT 13 - OCT 26	NOT AVAILABLE	NOT AVAILABLE
17	OCT 27 - NOV 9	NOT AVAILABLE	NOT AVAILABLE
18	NOV 10 - NOV 23	NOT AVAILABLE	NOT AVAILABLE
19	NOV 24 - DEC 7	NOT AVAILABLE	NOT AVAILABLE
20	DEC 8 - DEC 21	NOT AVAILABLE	NOT AVAILABLE
21	DEC 22 - JAN 4	NOT AVAILABLE	NOT AVAILABLE
22	JAN 5 - JAN 18	NOT AVAILABLE	NOT AVAILABLE
23	JAN 19 - FEB 1	NOT AVAILABLE	NOT AVAILABLE
24	FEB 2 - FEB 15	NOT AVAILABLE	NOT AVAILABLE
25	FEB 16 - FEB 29	NOT AVAILABLE	NOT AVAILABLE
26	MAR 1 - MAR 14	NOT AVAILABLE	NOT AVAILABLE
27	MAR 15 - MAR 28	NOT AVAILABLE	NOT AVAILABLE

Summary for MINNEDOSA		
Average	0.9	1.15
Minimum	0.7	1.00
Maximum	1.0	1.20
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	7%	
Number of Samples	14	

Fluoride Control Data 2007 / 2008

LOCATION MORDEN
OPERATOR Al Spearman
PHONE 822-5707

FLUORIDATOR Prominent
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.32

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.45
2	MAR 31 - APR 13	1.1	1.19
3	APR 14 - APR 27	1.0	1.16
4	APR 28 - MAY 11	1.0	1.19
5	MAY 12 - MAY 25	1.0	1.21
6	MAY 26 - JUN 8	1.0	1.14
7	JUN 9 - JUN 22	0.9	1.11
8	JUN 23 - JUL 6	1.1	1.04
9	JUL 7 - JUL 20	1.0	1.05
10	JUL 21 - AUG 3	0.9	1.12
11	AUG 4 - AUG 17	1.0	1.16
12	AUG 18 - AUG 31	0.9	1.14
13	SEP 1 - SEP 14	1.1	1.10
14	SEP 15 - SEP 28	1.1	1.12
15	SEP 29 - OCT 12	1.1	1.11
16	OCT 13 - OCT 26	1.2	1.11
17	OCT 27 - NOV 9	1.2	1.10
18	NOV 10 - NOV 23	1.1	1.05
19	NOV 24 - DEC 7	1.1	1.03
20	DEC 8 - DEC 21	1.2	1.04
21	DEC 22 - JAN 4	1.0	1.11
22	JAN 5 - JAN 18	1.0	1.11
23	JAN 19 - FEB 1	1.0	1.12
24	FEB 2 - FEB 15	1.0	1.16
25	FEB 16 - FEB 29	1.0	1.14
26	MAR 1 - MAR 14	1.1	1.19
27	MAR 15 - MAR 28	1.0	1.09

Summary for MORDEN

Average	1.0	1.13
Minimum	0.9	1.03
Maximum	1.2	1.45
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION MORRIS
OPERATOR Byron Klassen
PHONE 746-2531

FLUORIDATOR Prominent
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.22

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.2	1.24
2	MAR 31 - APR 13	1.2	NOT AVAILABLE
3	APR 14 - APR 27	1.2	0.99
4	APR 28 - MAY 11	1.2	0.94
5	MAY 12 - MAY 25	1.3	1.20
6	MAY 26 - JUN 8	1.3	1.02
7	JUN 9 - JUN 22	1.3	1.01
8	JUN 23 - JUL 6	1.3	1.14
9	JUL 7 - JUL 20	1.1	0.95
10	JUL 21 - AUG 3	1.0	0.96
11	AUG 4 - AUG 17	1.0	0.98
12	AUG 18 - AUG 31	1.0	0.89
13	SEP 1 - SEP 14	1.2	1.01
14	SEP 15 - SEP 28	1.2	1.17
15	SEP 29 - OCT 12	1.2	1.00
16	OCT 13 - OCT 26	1.1	0.94
17	OCT 27 - NOV 9	1.1	0.77
18	NOV 10 - NOV 23	1.2	0.84
19	NOV 24 - DEC 7	1.2	0.00
20	DEC 8 - DEC 21	1.0	0.79
21	DEC 22 - JAN 4	1.0	0.95
22	JAN 5 - JAN 18	0.8	0.74
23	JAN 19 - FEB 1	1.0	0.91
24	FEB 2 - FEB 15	1.0	1.04
25	FEB 16 - FEB 29	1.0	0.96
26	MAR 1 - MAR 14	1.1	0.91
27	MAR 15 - MAR 28	1.0	0.80

Summary for MORRIS

Average	1.1	0.93
Minimum	0.8	0.00
Maximum	1.3	1.24
Samples Above Limit	4	
Samples Below Limits	0	
% Outside Limits:	15%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	NEEPAWA	FLUORIDATOR	W&T A690
OPERATOR	Dan Wagner	CHEMICAL	H2SiF6 25 %
PHONE	476-7626	NATURAL FLUORIDE	0.24

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	1.36
2	MAR 31 - APR 13	0.8	0.89
3	APR 14 - APR 27	0.8	0.59
4	APR 28 - MAY 11	0.6	0.73
5	MAY 12 - MAY 25	0.9	0.88
6	MAY 26 - JUN 8	0.7	0.89
7	JUN 9 - JUN 22	0.8	0.69
8	JUN 23 - JUL 6	0.8	1.22
9	JUL 7 - JUL 20	0.6	1.22
10	JUL 21 - AUG 3	0.6	0.72
11	AUG 4 - AUG 17	0.7	0.68
12	AUG 18 - AUG 31	0.8	1.07
13	SEP 1 - SEP 14	0.9	0.75
14	SEP 15 - SEP 28	0.9	0.98
15	SEP 29 - OCT 12	0.7	0.90
16	OCT 13 - OCT 26	1.0	0.90
17	OCT 27 - NOV 9	0.9	0.70
18	NOV 10 - NOV 23	0.8	0.99
19	NOV 24 - DEC 7	1.1	1.03
20	DEC 8 - DEC 21	0.9	0.70
21	DEC 22 - JAN 4	0.7	0.70
22	JAN 5 - JAN 18	0.8	0.75
23	JAN 19 - FEB 1	0.9	0.96
24	FEB 2 - FEB 15	0.9	0.99
25	FEB 16 - FEB 29	0.7	0.89
26	MAR 1 - MAR 14	1.1	1.03
27	MAR 15 - MAR 28	0.7	0.87

Summary for NEEPAWA

Average	0.8	0.89
Minimum	0.6	0.59
Maximum	1.1	1.36
Samples Above Limit	0	
Samples Below Limits	9	
% Outside Limits:	33%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	NORWAY HOUSE COMMUNITY COUNCIL	FLUORIDATOR	Prominent
OPERATOR	Steve Mowatt	CHEMICAL	H2SiF6 25 %
PHONE	359-6719	NATURAL FLUORIDE	0.21

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	NOT AVAILABLE	NOT AVAILABLE
2	MAR 31 - APR 13	NOT AVAILABLE	NOT AVAILABLE
3	APR 14 - APR 27	NOT AVAILABLE	NOT AVAILABLE
4	APR 28 - MAY 11	NOT AVAILABLE	NOT AVAILABLE
5	MAY 12 - MAY 25	NOT AVAILABLE	NOT AVAILABLE
6	MAY 26 - JUN 8	NOT AVAILABLE	NOT AVAILABLE
7	JUN 9 - JUN 22	NOT AVAILABLE	NOT AVAILABLE
8	JUN 23 - JUL 6	NOT AVAILABLE	NOT AVAILABLE
9	JUL 7 - JUL 20	NOT AVAILABLE	NOT AVAILABLE
10	JUL 21 - AUG 3	NOT AVAILABLE	NOT AVAILABLE
11	AUG 4 - AUG 17	NOT AVAILABLE	NOT AVAILABLE
12	AUG 18 - AUG 31	NOT AVAILABLE	NOT AVAILABLE
13	SEP 1 - SEP 14	NOT AVAILABLE	NOT AVAILABLE
14	SEP 15 - SEP 28	NOT AVAILABLE	NOT AVAILABLE
15	SEP 29 - OCT 12	NOT AVAILABLE	NOT AVAILABLE
16	OCT 13 - OCT 26	NOT AVAILABLE	NOT AVAILABLE
17	OCT 27 - NOV 9	NOT AVAILABLE	NOT AVAILABLE
18	NOV 10 - NOV 23	NOT AVAILABLE	NOT AVAILABLE
19	NOV 24 - DEC 7	NOT AVAILABLE	NOT AVAILABLE
20	DEC 8 - DEC 21	NOT AVAILABLE	NOT AVAILABLE
21	DEC 22 - JAN 4	NOT AVAILABLE	NOT AVAILABLE
22	JAN 5 - JAN 18	0.8	0.65
23	JAN 19 - FEB 1	0.7	0.65
24	FEB 2 - FEB 15	0.7	0.62
25	FEB 16 - FEB 29	0.7	0.58
26	MAR 1 - MAR 14	0.8	0.63
27	MAR 15 - MAR 28	1.0	0.59

Summary for NORWAY HOUSE COMMUNITY COUNCIL

Average	0.8	0.62
Minimum	0.7	0.58
Maximum	1.0	0.65
Samples Above Limit	0	
Samples Below Limits	3	
% Outside Limits:	50%	
Number of Samples	6	

Fluoride Control Data 2007 / 2008

LOCATION	PILOT MOUND	FLUORIDATOR	LMI Saturator
OPERATOR	Corey McCoy	CHEMICAL	NaF 4 %
PHONE	825-2115	NATURAL FLUORIDE	0.21

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.6	1.10
2	MAR 31 - APR 13	0.7	0.89
3	APR 14 - APR 27	1.0	1.18
4	APR 28 - MAY 11	0.9	1.06
5	MAY 12 - MAY 25	0.9	1.00
6	MAY 26 - JUN 8	1.3	1.18
7	JUN 9 - JUN 22	1.1	1.20
8	JUN 23 - JUL 6	1.1	1.13
9	JUL 7 - JUL 20	1.0	1.25
10	JUL 21 - AUG 3	0.8	1.11
11	AUG 4 - AUG 17	0.9	1.02
12	AUG 18 - AUG 31	0.9	1.12
13	SEP 1 - SEP 14	1.1	1.15
14	SEP 15 - SEP 28	0.7	0.81
15	SEP 29 - OCT 12	0.7	0.87
16	OCT 13 - OCT 26	1.2	1.21
17	OCT 27 - NOV 9	2.4	2.27
18	NOV 10 - NOV 23	0.9	1.02
19	NOV 24 - DEC 7	0.4	0.65
20	DEC 8 - DEC 21	0.7	0.95
21	DEC 22 - JAN 4	0.7	0.73
22	JAN 5 - JAN 18	0.7	0.84
23	JAN 19 - FEB 1	0.8	0.81
24	FEB 2 - FEB 15	0.9	0.74
25	FEB 16 - FEB 29	0.8	0.74
26	MAR 1 - MAR 14	1.0	0.92
27	MAR 15 - MAR 28	1.0	0.99

Summary for PILOT MOUND		
Average	0.9	1.03
Minimum	0.4	0.65
Maximum	2.4	2.27
Samples Above Limit	2	
Samples Below Limits	8	
% Outside Limits:	37%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION PORTAGE LA PRAIRIE
OPERATOR Doug Campbell
PHONE 239-8373

FLUORIDATOR W&T A690
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	1.09
2	MAR 31 - APR 13	1.5	1.49
3	APR 14 - APR 27	1.2	NOT AVAILABLE
4	APR 28 - MAY 11	1.2	1.10
5	MAY 12 - MAY 25	1.1	1.20
6	MAY 26 - JUN 8	1.2	1.03
7	JUN 9 - JUN 22	1.2	1.18
8	JUN 23 - JUL 6	1.0	1.12
9	JUL 7 - JUL 20	1.2	1.25
10	JUL 21 - AUG 3	1.0	1.13
11	AUG 4 - AUG 17	1.0	1.21
12	AUG 18 - AUG 31	1.1	1.16
13	SEP 1 - SEP 14	1.3	1.21
14	SEP 15 - SEP 28	1.2	1.10
15	SEP 29 - OCT 12	1.3	1.17
16	OCT 13 - OCT 26	1.4	1.19
17	OCT 27 - NOV 9	1.3	1.12
18	NOV 10 - NOV 23	1.3	1.12
19	NOV 24 - DEC 7	1.2	1.09
20	DEC 8 - DEC 21	1.0	1.02
21	DEC 22 - JAN 4	0.9	0.88
22	JAN 5 - JAN 18	0.6	0.87
23	JAN 19 - FEB 1	0.8	0.95
24	FEB 2 - FEB 15	0.9	1.00
25	FEB 16 - FEB 29	0.8	0.91
26	MAR 1 - MAR 14	1.0	1.08
27	MAR 15 - MAR 28	0.7	0.78

Summary for PORTAGE LA PRAIRIE

Average	1.1	1.09
Minimum	0.6	0.78
Maximum	1.5	1.49
Samples Above Limit	6	
Samples Below Limits	2	
% Outside Limits:	30%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	RESTON	FLUORIDATOR	W&T A745
OPERATOR	Ken Moore	CHEMICAL	NaF 4 %
PHONE	877-3862	NATURAL FLUORIDE	0.13

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	1.00
2	MAR 31 - APR 13	0.8	0.95
3	APR 14 - APR 27	0.8	0.90
4	APR 28 - MAY 11	1.2	1.05
5	MAY 12 - MAY 25	1.1	1.10
6	MAY 26 - JUN 8	1.0	1.00
7	JUN 9 - JUN 22	1.0	1.00
8	JUN 23 - JUL 6	1.0	1.00
9	JUL 7 - JUL 20	1.0	1.00
10	JUL 21 - AUG 3	0.9	1.00
11	AUG 4 - AUG 17	1.0	1.00
12	AUG 18 - AUG 31	1.0	1.10
13	SEP 1 - SEP 14	1.1	1.10
14	SEP 15 - SEP 28	1.0	1.00
15	SEP 29 - OCT 12	1.0	0.95
16	OCT 13 - OCT 26	1.0	0.95
17	OCT 27 - NOV 9	1.2	1.10
18	NOV 10 - NOV 23	1.2	1.10
19	NOV 24 - DEC 7	1.2	1.05
20	DEC 8 - DEC 21	1.4	1.10
21	DEC 22 - JAN 4	0.9	0.95
22	JAN 5 - JAN 18	1.1	1.05
23	JAN 19 - FEB 1	1.2	1.15
24	FEB 2 - FEB 15	1.0	1.05
25	FEB 16 - FEB 29	1.1	0.95
26	MAR 1 - MAR 14	0.9	1.00
27	MAR 15 - MAR 28	1.1	1.00

Summary for RESTON		
Average	1.0	1.02
Minimum	0.8	0.90
Maximum	1.4	1.15
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	RIVERS	FLUORIDATOR	LMI Saturator
OPERATOR	Randy King	CHEMICAL	NaF 4 %
PHONE	328-5250	NATURAL FLUORIDE	0.18

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.8	0.74
2	MAR 31 - APR 13	1.0	0.97
3	APR 14 - APR 27	1.0	0.84
4	APR 28 - MAY 11	1.0	0.90
5	MAY 12 - MAY 25	1.0	1.10
6	MAY 26 - JUN 8	1.3	1.23
7	JUN 9 - JUN 22	1.0	0.76
8	JUN 23 - JUL 6	1.2	0.99
9	JUL 7 - JUL 20	1.1	1.21
10	JUL 21 - AUG 3	0.9	0.65
11	AUG 4 - AUG 17	1.0	0.76
12	AUG 18 - AUG 31	0.9	0.85
13	SEP 1 - SEP 14	1.2	0.84
14	SEP 15 - SEP 28	1.2	0.89
15	SEP 29 - OCT 12	1.1	0.94
16	OCT 13 - OCT 26	1.1	0.82
17	OCT 27 - NOV 9	1.2	1.10
18	NOV 10 - NOV 23	1.8	0.92
19	NOV 24 - DEC 7	1.3	1.08
20	DEC 8 - DEC 21	1.2	0.88
21	DEC 22 - JAN 4	1.0	1.06
22	JAN 5 - JAN 18	0.8	0.97
23	JAN 19 - FEB 1	1.0	1.10
24	FEB 2 - FEB 15	1.0	0.92
25	FEB 16 - FEB 29	1.0	1.21
26	MAR 1 - MAR 14	1.0	1.15
27	MAR 15 - MAR 28	1.0	1.13

Summary for RIVERS		
Average	1.1	0.96
Minimum	0.8	0.65
Maximum	1.8	1.23
Samples Above Limit	3	
Samples Below Limits	0	
% Outside Limits:	11%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION ROBLIN	FLUORIDATOR W&T A745
OPERATOR Don Todorovich	CHEMICAL NaF 4 %
PHONE 937-8333	NATURAL FLUORIDE 0.26

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	1.00
2	MAR 31 - APR 13	0.9	1.00
3	APR 14 - APR 27	0.9	1.00
4	APR 28 - MAY 11	1.0	1.05
5	MAY 12 - MAY 25	0.9	1.00
6	MAY 26 - JUN 8	1.0	1.05
7	JUN 9 - JUN 22	0.9	1.10
8	JUN 23 - JUL 6	0.8	1.00
9	JUL 7 - JUL 20	0.9	1.10
10	JUL 21 - AUG 3	0.9	1.10
11	AUG 4 - AUG 17	1.0	1.10
12	AUG 18 - AUG 31	1.0	1.10
13	SEP 1 - SEP 14	1.1	1.10
14	SEP 15 - SEP 28	1.0	1.15
15	SEP 29 - OCT 12	1.0	1.01
16	OCT 13 - OCT 26	1.1	0.99
17	OCT 27 - NOV 9	1.0	1.13
18	NOV 10 - NOV 23	1.1	1.02
19	NOV 24 - DEC 7	0.9	1.05
20	DEC 8 - DEC 21	1.1	1.13
21	DEC 22 - JAN 4	0.9	9.00
22	JAN 5 - JAN 18	0.9	1.16
23	JAN 19 - FEB 1	0.8	0.96
24	FEB 2 - FEB 15	0.8	1.11
25	FEB 16 - FEB 29	0.8	1.11
26	MAR 1 - MAR 14	1.0	1.05
27	MAR 15 - MAR 28	1.0	1.17

Summary for ROBLIN		
Average	0.9	1.36
Minimum	0.8	0.96
Maximum	1.1	9.00
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION ROSSBURN
OPERATOR Perry Kretai
PHONE 859-2762

FLUORIDATOR W&T A745
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.1

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.00
2	MAR 31 - APR 13	0.9	1.00
3	APR 14 - APR 27	0.9	1.00
4	APR 28 - MAY 11	1.0	0.90
5	MAY 12 - MAY 25	0.9	0.90
6	MAY 26 - JUN 8	0.9	0.80
7	JUN 9 - JUN 22	1.0	1.00
8	JUN 23 - JUL 6	1.0	0.90
9	JUL 7 - JUL 20	0.9	0.90
10	JUL 21 - AUG 3	0.9	0.90
11	AUG 4 - AUG 17	1.0	1.00
12	AUG 18 - AUG 31	1.0	1.00
13	SEP 1 - SEP 14	1.1	0.90
14	SEP 15 - SEP 28	0.9	0.90
15	SEP 29 - OCT 12	0.9	0.80
16	OCT 13 - OCT 26	0.8	0.70
17	OCT 27 - NOV 9	0.9	0.80
18	NOV 10 - NOV 23	0.9	0.60
19	NOV 24 - DEC 7	1.2	0.70
20	DEC 8 - DEC 21	1.2	1.10
21	DEC 22 - JAN 4	1.0	1.00
22	JAN 5 - JAN 18	0.8	0.50
23	JAN 19 - FEB 1	1.3	1.10
24	FEB 2 - FEB 15	1.1	1.00
25	FEB 16 - FEB 29	1.0	0.80
26	MAR 1 - MAR 14	1.0	0.80
27	MAR 15 - MAR 28	1.0	0.90

Summary for ROSSBURN

Average	1.0	0.89
Minimum	0.8	0.50
Maximum	1.3	1.10
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	RUSSELL	FLUORIDATOR	LMI A151
OPERATOR	Mark Moan	CHEMICAL	NaF 4 %
PHONE	773-2253	NATURAL FLUORIDE	0.21

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.06
2	MAR 31 - APR 13	1.1	1.04
3	APR 14 - APR 27	1.2	1.09
4	APR 28 - MAY 11	1.2	1.09
5	MAY 12 - MAY 25	1.1	1.04
6	MAY 26 - JUN 8	1.1	1.07
7	JUN 9 - JUN 22	1.2	1.05
8	JUN 23 - JUL 6	1.2	1.02
9	JUL 7 - JUL 20	1.0	1.14
10	JUL 21 - AUG 3	1.0	1.02
11	AUG 4 - AUG 17	1.0	1.11
12	AUG 18 - AUG 31	1.1	1.13
13	SEP 1 - SEP 14	1.3	1.15
14	SEP 15 - SEP 28	1.2	1.03
15	SEP 29 - OCT 12	1.2	1.13
16	OCT 13 - OCT 26	1.1	1.06
17	OCT 27 - NOV 9	1.1	1.08
18	NOV 10 - NOV 23	1.2	1.00
19	NOV 24 - DEC 7	1.1	1.02
20	DEC 8 - DEC 21	NOT AVAILABLE	NOT AVAILABLE
21	DEC 22 - JAN 4	1.0	1.00
22	JAN 5 - JAN 18	1.1	1.11
23	JAN 19 - FEB 1	1.0	1.12
24	FEB 2 - FEB 15	1.0	1.13
25	FEB 16 - FEB 29	1.1	1.04
26	MAR 1 - MAR 14	1.0	1.02
27	MAR 15 - MAR 28	1.1	1.01

Summary for RUSSELL		
Average	1.1	1.07
Minimum	1.0	1.00
Maximum	1.3	1.15
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	26	

Fluoride Control Data 2007 / 2008

LOCATION	SANFORD (RM MACDONALD)	FLUORIDATOR	W&T
OPERATOR	David Eppler	CHEMICAL	H2SiF6 25 %
PHONE	736-2255	NATURAL FLUORIDE	0.1

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	1.15
2	MAR 31 - APR 13	0.9	1.16
3	APR 14 - APR 27	1.0	1.06
4	APR 28 - MAY 11	1.0	1.12
5	MAY 12 - MAY 25	1.0	1.10
6	MAY 26 - JUN 8	1.1	1.11
7	JUN 9 - JUN 22	0.9	1.01
8	JUN 23 - JUL 6	1.1	1.09
9	JUL 7 - JUL 20	1.0	0.99
10	JUL 21 - AUG 3	0.9	1.04
11	AUG 4 - AUG 17	0.9	1.00
12	AUG 18 - AUG 31	0.9	1.08
13	SEP 1 - SEP 14	1.1	1.09
14	SEP 15 - SEP 28	1.1	1.10
15	SEP 29 - OCT 12	1.1	1.19
16	OCT 13 - OCT 26	1.1	1.23
17	OCT 27 - NOV 9	1.1	1.08
18	NOV 10 - NOV 23	1.1	1.18
19	NOV 24 - DEC 7	1.2	1.14
20	DEC 8 - DEC 21	1.0	1.06
21	DEC 22 - JAN 4	1.0	1.02
22	JAN 5 - JAN 18	1.0	1.07
23	JAN 19 - FEB 1	1.0	1.12
24	FEB 2 - FEB 15	1.0	1.20
25	FEB 16 - FEB 29	0.9	1.16
26	MAR 1 - MAR 14	1.0	0.67
27	MAR 15 - MAR 28	1.0	1.12

Summary for SANFORD (RM MACDONALD)		
Average	1.0	1.09
Minimum	0.9	0.67
Maximum	1.2	1.23
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION SAPOTAWEYAK
OPERATOR Horace Cook
PHONE 587-2125

FLUORIDATOR
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.31

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.8	NOT AVAILABLE
2	MAR 31 - APR 13	0.7	NOT AVAILABLE
3	APR 14 - APR 27	0.7	NOT AVAILABLE
4	APR 28 - MAY 11	0.7	NOT AVAILABLE
5	MAY 12 - MAY 25	0.9	NOT AVAILABLE
6	MAY 26 - JUN 8	0.8	NOT AVAILABLE
7	JUN 9 - JUN 22	0.7	NOT AVAILABLE
8	JUN 23 - JUL 6	0.6	NOT AVAILABLE
9	JUL 7 - JUL 20	0.5	NOT AVAILABLE
10	JUL 21 - AUG 3	0.6	NOT AVAILABLE
11	AUG 4 - AUG 17	NOT AVAILABLE	NOT AVAILABLE
12	AUG 18 - AUG 31	NOT AVAILABLE	NOT AVAILABLE
13	SEP 1 - SEP 14	0.7	NOT AVAILABLE
14	SEP 15 - SEP 28	0.8	NOT AVAILABLE
15	SEP 29 - OCT 12	0.9	0.00
16	OCT 13 - OCT 26	0.8	0.00
17	OCT 27 - NOV 9	0.5	0.00
18	NOV 10 - NOV 23	0.4	0.00
19	NOV 24 - DEC 7	0.9	0.00
20	DEC 8 - DEC 21	0.8	0.00
21	DEC 22 - JAN 4	0.7	0.00
22	JAN 5 - JAN 18	0.3	0.00
23	JAN 19 - FEB 1	0.2	0.00
24	FEB 2 - FEB 15	0.6	0.00
25	FEB 16 - FEB 29	1.0	0.00
26	MAR 1 - MAR 14	1.0	0.00
27	MAR 15 - MAR 28	1.0	0.00

Summary for SAPOTAWEYAK

Average	0.7	0.00
Minimum	0.2	0.00
Maximum	1.0	0.00
Samples Above Limit	0	
Samples Below Limits	14	
% Outside Limits:	56%	
Number of Samples	25	

Fluoride Control Data 2007 / 2008

LOCATION SHILO
OPERATOR Bill Burke
PHONE 765-4723

FLUORIDATOR LMI Saturator
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.05

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.7	0.70
2	MAR 31 - APR 13	NOT AVAILABLE	NOT AVAILABLE
3	APR 14 - APR 27	0.8	0.80
4	APR 28 - MAY 11	1.0	0.75
5	MAY 12 - MAY 25	0.9	0.67
6	MAY 26 - JUN 8	1.1	0.75
7	JUN 9 - JUN 22	1.0	0.92
8	JUN 23 - JUL 6	1.1	0.91
9	JUL 7 - JUL 20	0.8	0.77
10	JUL 21 - AUG 3	0.6	0.67
11	AUG 4 - AUG 17	0.5	0.60
12	AUG 18 - AUG 31	1.0	0.88
13	SEP 1 - SEP 14	1.1	0.88
14	SEP 15 - SEP 28	1.2	0.90
15	SEP 29 - OCT 12	1.2	1.17
16	OCT 13 - OCT 26	1.1	0.83
17	OCT 27 - NOV 9	1.1	0.95
18	NOV 10 - NOV 23	1.0	0.78
19	NOV 24 - DEC 7	1.1	0.93
20	DEC 8 - DEC 21	1.2	1.04
21	DEC 22 - JAN 4	1.0	1.00
22	JAN 5 - JAN 18	1.0	1.05
23	JAN 19 - FEB 1	1.0	0.95
24	FEB 2 - FEB 15	1.0	0.95
25	FEB 16 - FEB 29	1.0	0.92
26	MAR 1 - MAR 14	1.0	0.94
27	MAR 15 - MAR 28	1.0	0.89

Summary for SHILO

Average	1.0	0.87
Minimum	0.5	0.60
Maximum	1.2	1.17
Samples Above Limit	0	
Samples Below Limits	3	
% Outside Limits:	12%	
Number of Samples	26	

Fluoride Control Data 2007 / 2008

LOCATION SOMERSET
OPERATOR Remi Messner
PHONE 744-2179

FLUORIDATOR
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE .02

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.4	0.93
2	MAR 31 - APR 13	1.4	0.86
3	APR 14 - APR 27	1.4	0.82
4	APR 28 - MAY 11	1.9	1.00
5	MAY 12 - MAY 25	2.0	1.08
6	MAY 26 - JUN 8	2.0	0.99
7	JUN 9 - JUN 22	1.9	1.03
8	JUN 23 - JUL 6	1.8	0.98
9	JUL 7 - JUL 20	1.7	0.94
10	JUL 21 - AUG 3	1.5	1.01
11	AUG 4 - AUG 17	1.7	1.00
12	AUG 18 - AUG 31	1.1	0.63
13	SEP 1 - SEP 14	1.0	0.66
14	SEP 15 - SEP 28	1.1	0.63
15	SEP 29 - OCT 12	0.9	0.46
16	OCT 13 - OCT 26	0.9	0.62
17	OCT 27 - NOV 9	1.0	0.35
18	NOV 10 - NOV 23	1.0	0.55
19	NOV 24 - DEC 7	1.0	0.63
20	DEC 8 - DEC 21	1.0	0.46
21	DEC 22 - JAN 4	0.9	0.38
22	JAN 5 - JAN 18	0.8	0.58
23	JAN 19 - FEB 1	0.8	0.53
24	FEB 2 - FEB 15	0.9	0.51
25	FEB 16 - FEB 29	1.0	0.77
26	MAR 1 - MAR 14	1.0	0.52
27	MAR 15 - MAR 28	1.0	0.57

Summary for SOMERSET		
Average	1.3	0.72
Minimum	0.8	0.35
Maximum	2.0	1.08
Samples Above Limit	11	
Samples Below Limits	0	
% Outside Limits:	41%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION SOURIS
OPERATOR Don Bodin and Kelvin Kowalchuk
PHONE 483-2169

FLUORIDATOR LMI Saturator
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.8	0.89
2	MAR 31 - APR 13	1.0	1.04
3	APR 14 - APR 27	1.0	1.13
4	APR 28 - MAY 11	1.0	0.92
5	MAY 12 - MAY 25	1.0	0.98
6	MAY 26 - JUN 8	1.0	0.83
7	JUN 9 - JUN 22	1.0	0.93
8	JUN 23 - JUL 6	1.2	1.07
9	JUL 7 - JUL 20	0.9	1.00
10	JUL 21 - AUG 3	0.9	1.31
11	AUG 4 - AUG 17	1.0	1.02
12	AUG 18 - AUG 31	1.2	1.11
13	SEP 1 - SEP 14	1.1	1.00
14	SEP 15 - SEP 28	1.2	1.03
15	SEP 29 - OCT 12	1.3	1.17
16	OCT 13 - OCT 26	1.3	1.16
17	OCT 27 - NOV 9	1.2	1.06
18	NOV 10 - NOV 23	1.4	0.93
19	NOV 24 - DEC 7	1.5	1.21
20	DEC 8 - DEC 21	1.4	1.09
21	DEC 22 - JAN 4	1.1	1.04
22	JAN 5 - JAN 18	1.3	1.26
23	JAN 19 - FEB 1	1.1	1.10
24	FEB 2 - FEB 15	1.0	0.94
25	FEB 16 - FEB 29	1.1	1.06
26	MAR 1 - MAR 14	1.2	1.17
27	MAR 15 - MAR 28	1.0	0.90

Summary for SOURIS

Average	1.1	1.05
Minimum	0.8	0.83
Maximum	1.5	1.31
Samples Above Limit	6	
Samples Below Limits	0	
% Outside Limits:	22%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	STEINBACH	FLUORIDATOR	Pulsatron
OPERATOR	Jason Hiebert	CHEMICAL	H2SiF6 25 %
PHONE	326-9877	NATURAL FLUORIDE	0.39

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	0.85
2	MAR 31 - APR 13	1.0	0.88
3	APR 14 - APR 27	1.0	0.88
4	APR 28 - MAY 11	0.9	0.84
5	MAY 12 - MAY 25	1.0	0.85
6	MAY 26 - JUN 8	1.0	0.88
7	JUN 9 - JUN 22	0.9	0.87
8	JUN 23 - JUL 6	0.9	0.80
9	JUL 7 - JUL 20	1.0	0.84
10	JUL 21 - AUG 3	0.8	0.92
11	AUG 4 - AUG 17	1.0	0.85
12	AUG 18 - AUG 31	0.9	0.83
13	SEP 1 - SEP 14	1.1	0.84
14	SEP 15 - SEP 28	1.0	0.81
15	SEP 29 - OCT 12	1.0	0.87
16	OCT 13 - OCT 26	1.0	0.87
17	OCT 27 - NOV 9	1.0	0.94
18	NOV 10 - NOV 23	0.9	0.89
19	NOV 24 - DEC 7	1.1	0.87
20	DEC 8 - DEC 21	1.0	0.84
21	DEC 22 - JAN 4	0.9	0.83
22	JAN 5 - JAN 18	0.8	0.87
23	JAN 19 - FEB 1	1.0	0.87
24	FEB 2 - FEB 15	0.8	0.87
25	FEB 16 - FEB 29	0.9	0.86
26	MAR 1 - MAR 14	0.9	0.92
27	MAR 15 - MAR 28	1.0	0.85

Summary for STEINBACH		
Average	1.0	0.86
Minimum	0.8	0.80
Maximum	1.1	0.94
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	STEPHENFIELD	FLUORIDATOR	Prominent
OPERATOR	Paul Termeer	CHEMICAL	H2SiF6 25 %
PHONE	828-3434	NATURAL FLUORIDE	0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.2	0.77
2	MAR 31 - APR 13	1.2	0.78
3	APR 14 - APR 27	1.2	0.95
4	APR 28 - MAY 11	1.2	0.67
5	MAY 12 - MAY 25	1.1	1.00
6	MAY 26 - JUN 8	1.0	0.91
7	JUN 9 - JUN 22	0.9	1.00
8	JUN 23 - JUL 6	1.1	0.94
9	JUL 7 - JUL 20	1.0	0.93
10	JUL 21 - AUG 3	0.9	0.96
11	AUG 4 - AUG 17	1.0	1.07
12	AUG 18 - AUG 31	1.0	0.95
13	SEP 1 - SEP 14	1.1	0.92
14	SEP 15 - SEP 28	1.0	0.96
15	SEP 29 - OCT 12	1.1	0.94
16	OCT 13 - OCT 26	1.0	0.91
17	OCT 27 - NOV 9	1.0	0.87
18	NOV 10 - NOV 23	0.8	0.70
19	NOV 24 - DEC 7	0.8	0.77
20	DEC 8 - DEC 21	0.7	0.75
21	DEC 22 - JAN 4	0.7	0.77
22	JAN 5 - JAN 18	0.7	0.81
23	JAN 19 - FEB 1	0.6	0.84
24	FEB 2 - FEB 15	0.7	0.70
25	FEB 16 - FEB 29	0.6	0.86
26	MAR 1 - MAR 14	0.8	0.58
27	MAR 15 - MAR 28	0.9	0.85

Summary for STEPHENFIELD		
Average	0.9	0.86
Minimum	0.6	0.58
Maximum	1.2	1.07
Samples Above Limit	0	
Samples Below Limits	6	
% Outside Limits:	22%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION	SWAN RIVER	FLUORIDATOR	LMI A741
OPERATOR	Eric Arp	CHEMICAL	H2SiF6 25 %
PHONE	734-4586	NATURAL FLUORIDE	0.18

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.3	1.02
2	MAR 31 - APR 13	1.2	0.98
3	APR 14 - APR 27	1.3	1.13
4	APR 28 - MAY 11	1.0	1.05
5	MAY 12 - MAY 25	1.0	0.96
6	MAY 26 - JUN 8	1.2	1.09
7	JUN 9 - JUN 22	1.1	1.07
8	JUN 23 - JUL 6	1.2	1.07
9	JUL 7 - JUL 20	1.0	1.14
10	JUL 21 - AUG 3	0.9	0.95
11	AUG 4 - AUG 17	1.0	1.04
12	AUG 18 - AUG 31	1.0	1.10
13	SEP 1 - SEP 14	1.1	1.05
14	SEP 15 - SEP 28	1.2	1.07
15	SEP 29 - OCT 12	1.3	1.14
16	OCT 13 - OCT 26	1.2	1.04
17	OCT 27 - NOV 9	1.3	1.10
18	NOV 10 - NOV 23	1.3	1.01
19	NOV 24 - DEC 7	1.2	0.97
20	DEC 8 - DEC 21	1.2	1.01
21	DEC 22 - JAN 4	0.9	1.03
22	JAN 5 - JAN 18	0.9	1.00
23	JAN 19 - FEB 1	0.9	1.07
24	FEB 2 - FEB 15	0.9	1.04
25	FEB 16 - FEB 29	0.9	0.98
26	MAR 1 - MAR 14	1.0	1.00
27	MAR 15 - MAR 28	1.0	0.94

Summary for SWAN RIVER		
Average	1.1	1.04
Minimum	0.9	0.94
Maximum	1.3	1.14
Samples Above Limit	5	
Samples Below Limits	0	
% Outside Limits:	19%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION THE PAS
OPERATOR Ronald Stewart
PHONE 627-1142

FLUORIDATOR W&T 32-050
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.15

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.0	0.90
2	MAR 31 - APR 13	1.0	1.10
3	APR 14 - APR 27	1.1	1.10
4	APR 28 - MAY 11	1.1	1.40
5	MAY 12 - MAY 25	1.2	1.00
6	MAY 26 - JUN 8	1.2	1.10
7	JUN 9 - JUN 22	1.0	1.00
8	JUN 23 - JUL 6	1.2	1.00
9	JUL 7 - JUL 20	1.0	1.00
10	JUL 21 - AUG 3	1.0	1.00
11	AUG 4 - AUG 17	1.0	1.00
12	AUG 18 - AUG 31	1.1	1.00
13	SEP 1 - SEP 14	1.2	1.00
14	SEP 15 - SEP 28	1.2	1.00
15	SEP 29 - OCT 12	1.2	1.00
16	OCT 13 - OCT 26	1.0	0.90
17	OCT 27 - NOV 9	1.1	0.90
18	NOV 10 - NOV 23	1.2	0.90
19	NOV 24 - DEC 7	1.2	1.00
20	DEC 8 - DEC 21	1.4	1.00
21	DEC 22 - JAN 4	1.1	1.00
22	JAN 5 - JAN 18	1.0	1.00
23	JAN 19 - FEB 1	1.0	1.00
24	FEB 2 - FEB 15	1.0	0.90
25	FEB 16 - FEB 29	1.0	0.90
26	MAR 1 - MAR 14	1.1	0.96
27	MAR 15 - MAR 28	1.0	0.67

Summary for THE PAS

Average	1.1	0.99
Minimum	1.0	0.67
Maximum	1.4	1.40
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION TREHERNE	FLUORIDATOR LMI A741
OPERATOR Ken Lawrence	CHEMICAL H2SiF6 25 %
PHONE 723-2044	NATURAL FLUORIDE 0.32

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	0.90
2	MAR 31 - APR 13	0.9	0.90
3	APR 14 - APR 27	1.0	1.00
4	APR 28 - MAY 11	1.0	0.90
5	MAY 12 - MAY 25	1.0	0.90
6	MAY 26 - JUN 8	0.9	1.00
7	JUN 9 - JUN 22	0.9	1.00
8	JUN 23 - JUL 6	1.0	1.00
9	JUL 7 - JUL 20	0.9	0.90
10	JUL 21 - AUG 3	0.8	0.90
11	AUG 4 - AUG 17	0.9	1.00
12	AUG 18 - AUG 31	0.8	1.00
13	SEP 1 - SEP 14	1.1	1.00
14	SEP 15 - SEP 28	1.0	1.00
15	SEP 29 - OCT 12	1.0	1.00
16	OCT 13 - OCT 26	1.0	1.00
17	OCT 27 - NOV 9	1.0	1.00
18	NOV 10 - NOV 23	1.0	1.00
19	NOV 24 - DEC 7	1.0	1.00
20	DEC 8 - DEC 21	1.0	1.00
21	DEC 22 - JAN 4	0.9	1.00
22	JAN 5 - JAN 18	1.0	0.90
23	JAN 19 - FEB 1	0.9	0.90
24	FEB 2 - FEB 15	1.0	0.00
25	FEB 16 - FEB 29	1.0	0.00
26	MAR 1 - MAR 14	1.0	0.00
27	MAR 15 - MAR 28	1.0	1.00

Summary for TREHERNE		
Average	1.0	0.86
Minimum	0.8	0.00
Maximum	1.1	1.00
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION VIRDEN
OPERATOR Norm Baxter
PHONE 748-2440

FLUORIDATOR LMI A751
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.44

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.8	1.00
2	MAR 31 - APR 13	1.0	1.36
3	APR 14 - APR 27	1.0	0.91
4	APR 28 - MAY 11	0.9	0.80
5	MAY 12 - MAY 25	1.0	0.83
6	MAY 26 - JUN 8	0.9	0.91
7	JUN 9 - JUN 22	0.8	1.14
8	JUN 23 - JUL 6	NOT AVAILABLE	NOT AVAILABLE
9	JUL 7 - JUL 20	0.8	0.86
10	JUL 21 - AUG 3	0.9	0.78
11	AUG 4 - AUG 17	1.0	0.91
12	AUG 18 - AUG 31	0.8	0.50
13	SEP 1 - SEP 14	1.0	1.18
14	SEP 15 - SEP 28	0.9	1.16
15	SEP 29 - OCT 12	1.0	0.97
16	OCT 13 - OCT 26	1.0	1.13
17	OCT 27 - NOV 9	1.0	0.86
18	NOV 10 - NOV 23	1.0	1.08
19	NOV 24 - DEC 7	1.0	0.85
20	DEC 8 - DEC 21	1.0	0.59
21	DEC 22 - JAN 4	0.9	0.94
22	JAN 5 - JAN 18	0.9	0.80
23	JAN 19 - FEB 1	0.9	1.10
24	FEB 2 - FEB 15	0.8	0.90
25	FEB 16 - FEB 29	0.9	0.88
26	MAR 1 - MAR 14	1.0	0.96
27	MAR 15 - MAR 28	1.0	0.91

Summary for VIRDEN

Average	0.9	0.94
Minimum	0.8	0.50
Maximum	1.0	1.36
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2007 / 2008

LOCATION WABOWDEN
OPERATOR Clarence Bayer
PHONE 689-2165

FLUORIDATOR Prominent
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE < 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	0.97
2	MAR 31 - APR 13	1.2	NOT AVAILABLE
3	APR 14 - APR 27	1.4	1.30
4	APR 28 - MAY 11	1.4	1.30
5	MAY 12 - MAY 25	1.0	1.00
6	MAY 26 - JUN 8	1.0	1.00
7	JUN 9 - JUN 22	0.9	NOT AVAILABLE
8	JUN 23 - JUL 6	0.9	1.00
9	JUL 7 - JUL 20	1.0	1.10
10	JUL 21 - AUG 3	0.6	0.90
11	AUG 4 - AUG 17	0.8	0.90
12	AUG 18 - AUG 31	0.9	0.90
13	SEP 1 - SEP 14	1.1	0.80
14	SEP 15 - SEP 28	1.2	1.10
15	SEP 29 - OCT 12	1.3	1.20
16	OCT 13 - OCT 26	NOT AVAILABLE	NOT AVAILABLE
17	OCT 27 - NOV 9	0.1	0.90
18	NOV 10 - NOV 23	1.0	0.90
19	NOV 24 - DEC 7	1.1	1.20
20	DEC 8 - DEC 21	1.2	0.00
21	DEC 22 - JAN 4	1.0	1.00
22	JAN 5 - JAN 18	1.1	0.80
23	JAN 19 - FEB 1	1.0	1.20
24	FEB 2 - FEB 15	0.9	1.00
25	FEB 16 - FEB 29	0.8	0.90
26	MAR 1 - MAR 14	0.9	0.80
27	MAR 15 - MAR 28	1.1	0.80

Summary for WABOWDEN

Average	1.0	0.96
Minimum	0.1	0.00
Maximum	1.4	1.30
Samples Above Limit	3	
Samples Below Limits	2	
% Outside Limits:	19%	
Number of Samples	26	

Fluoride Control Data 2007 / 2008

LOCATION WINKLER
OPERATOR Travis Duff
PHONE 325-8711

FLUORIDATOR Prominent
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.26

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.9	0.84
2	MAR 31 - APR 13	0.9	0.88
3	APR 14 - APR 27	1.0	1.33
4	APR 28 - MAY 11	1.1	0.99
5	MAY 12 - MAY 25	1.1	1.03
6	MAY 26 - JUN 8	1.1	1.09
7	JUN 9 - JUN 22	1.0	1.11
8	JUN 23 - JUL 6	0.9	1.01
9	JUL 7 - JUL 20	0.8	0.91
10	JUL 21 - AUG 3	0.7	0.91
11	AUG 4 - AUG 17	0.8	0.88
12	AUG 18 - AUG 31	0.8	0.90
13	SEP 1 - SEP 14	0.8	0.83
14	SEP 15 - SEP 28	1.0	0.81
15	SEP 29 - OCT 12	0.9	0.94
16	OCT 13 - OCT 26	0.9	1.04
17	OCT 27 - NOV 9	0.7	0.67
18	NOV 10 - NOV 23	1.0	1.02
19	NOV 24 - DEC 7	0.9	0.80
20	DEC 8 - DEC 21	1.1	0.91
21	DEC 22 - JAN 4	0.9	1.10
22	JAN 5 - JAN 18	0.9	1.13
23	JAN 19 - FEB 1	0.8	0.90
24	FEB 2 - FEB 15	0.6	0.83
25	FEB 16 - FEB 29	0.6	0.00
26	MAR 1 - MAR 14	0.8	1.12
27	MAR 15 - MAR 28	1.0	0.89

Summary for WINKLER

Average	0.9	0.92
Minimum	0.6	0.00
Maximum	1.1	1.33
Samples Above Limit	0	
Samples Below Limits	4	
% Outside Limits:	15%	
Number of Samples	27	

Fluoride Control Data 2007 / 2008

LOCATION WINNIPEG
OPERATOR Renee Grosselle
PHONE 986-8359

FLUORIDATOR W&T
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.1

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	0.8	NOT AVAILABLE
2	MAR 31 - APR 13	0.9	NOT AVAILABLE
3	APR 14 - APR 27	0.9	NOT AVAILABLE
4	APR 28 - MAY 11	0.9	NOT AVAILABLE
5	MAY 12 - MAY 25	0.9	NOT AVAILABLE
6	MAY 26 - JUN 8	0.9	NOT AVAILABLE
7	JUN 9 - JUN 22	0.9	NOT AVAILABLE
8	JUN 23 - JUL 6	0.8	NOT AVAILABLE
9	JUL 7 - JUL 20	0.9	NOT AVAILABLE
10	JUL 21 - AUG 3	0.9	NOT AVAILABLE
11	AUG 4 - AUG 17	0.9	NOT AVAILABLE
12	AUG 18 - AUG 31	0.9	NOT AVAILABLE
13	SEP 1 - SEP 14	0.8	NOT AVAILABLE
14	SEP 15 - SEP 28	0.9	NOT AVAILABLE
15	SEP 29 - OCT 12	0.8	NOT AVAILABLE
16	OCT 13 - OCT 26	0.8	NOT AVAILABLE
17	OCT 27 - NOV 9	0.8	NOT AVAILABLE
18	NOV 10 - NOV 23	0.9	NOT AVAILABLE
19	NOV 24 - DEC 7	0.9	NOT AVAILABLE
20	DEC 8 - DEC 21	0.9	NOT AVAILABLE
21	DEC 22 - JAN 4	0.8	NOT AVAILABLE
22	JAN 5 - JAN 18	0.8	NOT AVAILABLE
23	JAN 19 - FEB 1	0.9	NOT AVAILABLE
24	FEB 2 - FEB 15	0.8	NOT AVAILABLE
25	FEB 16 - FEB 29	0.8	NOT AVAILABLE
26	MAR 1 - MAR 14	0.8	NOT AVAILABLE
27	MAR 15 - MAR 28	0.9	NOT AVAILABLE

Summary for WINNIPEG

Average	0.9
Minimum	0.8
Maximum	0.9
Samples Above Limit	0
Samples Below Limits	0
% Outside Limits:	0%
Number of Samples	27

Fluoride Control Data 2007 / 2008

LOCATION WINNIPEGOSIS
OPERATOR Dan Rempel
PHONE 656-4791

FLUORIDATOR LMI Saturator
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.15

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 17 - MAR 30	1.1	0.90
2	MAR 31 - APR 13	1.2	0.87
3	APR 14 - APR 27	1.3	0.95
4	APR 28 - MAY 11	1.2	0.92
5	MAY 12 - MAY 25	1.1	0.84
6	MAY 26 - JUN 8	1.2	0.92
7	JUN 9 - JUN 22	1.2	NOT AVAILABLE
8	JUN 23 - JUL 6	1.3	0.97
9	JUL 7 - JUL 20	1.0	0.91
10	JUL 21 - AUG 3	1.1	0.98
11	AUG 4 - AUG 17	1.1	0.89
12	AUG 18 - AUG 31	1.0	NOT AVAILABLE
13	SEP 1 - SEP 14	1.2	0.90
14	SEP 15 - SEP 28	1.2	0.83
15	SEP 29 - OCT 12	1.1	0.81
16	OCT 13 - OCT 26	1.1	0.78
17	OCT 27 - NOV 9	1.1	0.74
18	NOV 10 - NOV 23	1.2	0.75
19	NOV 24 - DEC 7	1.1	0.76
20	DEC 8 - DEC 21	1.2	0.00
21	DEC 22 - JAN 4	0.9	0.64
22	JAN 5 - JAN 18	0.9	0.70
23	JAN 19 - FEB 1	0.8	0.66
24	FEB 2 - FEB 15	0.7	0.73
25	FEB 16 - FEB 29	0.8	0.71
26	MAR 1 - MAR 14	1.0	0.74
27	MAR 15 - MAR 28	1.1	0.93

Summary for WINNIPEGOSIS

Average	1.1	0.79
Minimum	0.7	0.00
Maximum	1.3	0.98
Samples Above Limit	2	
Samples Below Limits	1	
% Outside Limits:	11%	
Number of Samples	27	